Well Construction Report
WISCONSIN UNIQUE WELL NUMBER: MW447

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: BERGNER, TOM	Phone #
Mailing Address: 7211 FAHLEY RD	
City: OSHKOSH	State: WI — Zip Code: 54904
County: Winnebago	Co. Permit #	Notification #	Completed: 10-23-1998
Well Constructor (Business Name): VAN DE YACHT BILL WTR WELL @ SPE	Lic. #: 4462	Facility ID # (Public Wells)
Address: 3671 MONROE RD, DE PERE WI 54115-9711	Well Plan Approval #	Approval Date (mm-dd-yyyy)
Hicap Permanent Well #	Common Well #	Specific Capacity: 0.7

1. Well Location

Town of VINLAND	Fire # (if avail.)
Street Address or Road Name and Number: 7211 FAHLEY RD	
Subdivision Name	Lot #	Block #
Latitude / Longitude in Decimal Degree (DD): 44.1525 °N -88.622 °W	Method Code: GCD013

NW	NW	Section	Township	Range
or Govt Lot #		5	19 N	16 E

2. Well Type New Well
of previous unique well # constructed in
Reason for replaced or reconstructed well ?
Construction Type: Drilled

3. Well serves 1 # of HOMES
Private,potable
Heat Exchange____# of drillholes
Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
9	Surface	67
6	67	121

Upper Enlarged Drillhole / Lower Open Bedrock

Yes — Rotary - Mud Circulation .....
Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
S	SAND	Surface	10
C	CLAY	10	25
N	SANDSTONE	25	121

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW BL STL PL END WELDED 18 97 280 A53 SAWHILL	Surface	68
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level
15 ft. below ground surface

10. Pump Test
Pumping level 60 ft. below surface
Pumping at 30 GP M for 1 Hrs.
Pumping Method ?

11. Well Is
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method HOSE PUMP

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT GROUT	Surface	67	15 S

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
BV		10-25-1998
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
CV		

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		90	Septic or Holding, or POWTS Tank		82

Comment:

Created On: 01-07-1999 Updated On: 10-18-2019 Review Status: