Well Construction Report
WISCONSIN UNIQUE WELL NUMBER MW448

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: GEIGER, FRANK	Phone #: ( )793-5219
Mailing Address: 2409 14TH ST	
City: TWO RIVERS	State: WI — Zip Code: 54241
County: Manitowoc	Co. Permit #: — Notification #: — Completed: 10-23-1998
Well Constructor (Business Name): VAN DE YACHT BILL WTR WELL @ SPE	Lic. #: 4462 — Facility ID # (Public Wells):
Address: 3671 MONROE RD, DE PERE WI 54115-9711	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #: — Common Well #: — Specific Capacity: 0.5	

1. Well Location

Town of GIBSON

Fire # (if avail.):

Street Address or Road Name and Number: MELNIK RD

Subdivision Name: — Lot #: — Block #:

Latitude / Longitude in Decimal Degree (DD): °N °W — Method Code:

NE SE or Govt Lot #: — Section: 31 — Township: 21 N — Range: 23 E

2. Well Type New Well

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of HOMES

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
9	Surface	62
6	62	262

Upper Enlarged Drillhole — Lower Open Bedrock

Yes — Rotary - Mud Circulation .....

Rotary - Air .....

Rotary - Air & Foam .....

Drill-Through Casing Hammer

Reverse Rotary

Cable-tool Bit ____in. dia...

Dual Rotary .....

Temp. Outer Casing ____in. dia

Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
C	CLAY	Surface	15
L	LIME	15	262

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW BL STL PL END WELDED 18 97 280 A53 SAWHILL	Surface	63
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

80 ft. below ground surface

10. Pump Test

Pumping level 140 ft. below surface

Pumping at 30 GP M for 1 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method HOSE PUMP

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT GROUT	Surface	62	15 S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
BV		10-25-1998
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
KV		

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		120	Septic or Holding, or POWTS Tank		110

Comment:

Created On: 01-07-1999 Updated On: 01-07-1999 Review Status: