

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				MX811		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner HALLE BUILDERS						Phone #		1. Well Location				Fire # (if avail.)	
Mailing Address 1113 HWY 64						Town of STANTON						976	
City NEW RICHMOND						State WI		Zip Code 54017				Street Address or Road Name and Number	
County St. Croix						Co. Permit #		Notification #		Completed 10-20-1998		COUNTY LINE RD	
Well Constructor (Business Name)						Lic. #		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD)		Method Code	
MARTELL STEVE PUMPS @ WELL DRLG						105		Well Plan Approval #		°N °W		NW NE Section Township Range or Govt Lot # 6 31 N 17 W	
Address PO BOX 28 SOMERSET WI 54025-0028						Approval Date (mm-dd-yyyy)		2. Well Type New Well					
Hicap Permanent Well #						Common Well #		Specific Capacity 0.7		of previous unique well # constructed in			
3. Well serves 1 # of HOME						Hicap Well ? No		Reason for replaced or reconstructed well ?					
Private, potable						Hicap Property ? No		Construction Type Drilled					
Heat Exchange ___ # of drillholes						Hicap Potable ?							
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock										
10 Surface 80			Yes Rotary - Mud Circulation										
6 80 120			Rotary - Air										
			Rotary - Air & Foam										
			Drill-Through Casing Hammer										
			Reverse Rotary										
			Cable-tool Bit ___ in. dia...										
			Dual Rotary										
			Temp. Outer Casing ___ in. dia										
			Removed? ___ depth ft. (If NO explain on back side)										
8. Geology													
Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...						From (ft.) To (ft.)				
S			SAND						Surface 79				
L			LIMEROCK						79 120				
6. Casing, Liner, Screen													
Dia. (in.)			Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.) To (ft.)		9. Static Water Level			11. Well Is	
6			19 45# FT ASTM A53 NEW PRIME T@C IPSCO				Surface 80		65 ft. below ground surface			12 in. above grade	
Dia. (in.)			Screen type, material & slot size				From (ft.) To (ft.)		10. Pump Test			Developed ? Yes	
									Pumping level 80 ft. below surface			Disinfected ? Yes	
									Pumping at 10 GP M for 1 Hrs.			Capped ? Yes	
									Pumping Method ?				
7. Grout or Other Sealing Material													
Method													
Kind of Sealing Material			From (ft.) To (ft.)		# Sacks Cement								
DRILL MUD @ CUTTINGS			Surface 80										
12. Notified Owner of need to fill & seal ?													
Filled & Sealed Well(s) as needed?													
13. Constructor / Supervisory Driller						Lic #		Date Signed					
SF								11-04-1998					
Drill Rig Operator						Lic or Reg #		Date Signed					
SFJ								11-04-1998					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		65	Building Overhang		20
			Septic or Holding, or POWTS Tank		45

Comment:

Created On: 01-19-1999

Updated On: 01-19-1999

Review Status: