

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				MY315		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner SRF DEVELOPMENT						Phone # (920)434-0598		1. Well Location				Fire # (if avail.)					
Mailing Address PO BOX 124						Town of SUAMICO											
City SUAMICO						State WI		Zip Code 54173									
County Brown		Co. Permit #		Notification #		Completed 11-02-1998		Subdivision Name FOREST PK				Lot # 11@12					
Well Constructor (Business Name) VAN DE YACHT LEO WELL DRILLING I				Lic. # 6097		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD)				Method Code					
Address 3383 OAK FOREST DR GREEN BAY WI 54313				Well Plan Approval #		Approval Date (mm-dd-yyyy)		°N		°W							
Hicap Permanent Well #		Common Well #		Specific Capacity 0.3		SW SE		Section 14		Township 25 N		Range 20 E					
3. Well serves 2 # of Private, potable						Hicap Well ? No		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? HOME									
Heat Exchange ___ # of drillholes						Hicap Property ? No											
Hicap Potable ?						Construction Type Drilled											
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method																	
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole Lower Open Bedrock Yes Rotary - Mud Circulation Yes Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)				Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
9		Surface		62						S		SAND		Surface		10	
6		62		122		C		CLAY		10		50					
						P		HARDPAN		50		62					
						L		LIMESTONE		62		122					
6. Casing, Liner, Screen																	
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level				11. Well Is			
6		NEW BLACK STEEL PLAIN END WELDED ASTM A53B 18 97#PER FT SAWHILL PIPE				Surface		62		20 ft. below ground surface				12 in. above grade			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		10. Pump Test				Developed ? Yes			
										Pumping level 100 ft. below surface				Disinfected ? Yes			
										Pumping at 25 GP M for 2 Hrs.				Capped ? Yes			
										Pumping Method ?							
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ?			
Method														Filled & Sealed Well(s) as needed? No			
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement											
DRILL SLURRY		Surface		62													
13. Constructor / Supervisory Driller														Lic #		Date Signed	
LV																11-02-1998	
Drill Rig Operator														Lic or Reg #		Date Signed	
TV																11-02-1998	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		30	Collector Sewer - San or Storm		140
Clearwater Sump		45	Foundation Drain to Clearwater		32
			Sewer - Building Sanitary		60

Comment:

Created On: 01-19-1999

Updated On: 01-19-1999

Review Status: