Well Construction Report
WISCONSIN UNIQUE WELL NUMBER MZ631

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: WHITE, ROBERT	Phone #: (920)648-8663
Mailing Address: W8155 ELM POINT RD	
City: LAKE MILLS	State: WI Zip Code: 53551
County: Jefferson	Co. Permit #:
Notification #	Completed: 03-02-1999
Well Constructor (Business Name): J F WERNER	Lic. #: 76
Facility ID # (Public Wells)	
Well Plan Approval #	
Address: N4018 HWY Y JEFFERSON WI 53549-9801	
Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #
Specific Capacity: 1.5	

1. Well Location

Town of LAKE MILLS

Fire # (if avail.)

Street Address or Road Name and Number: W8155 ELM POINT RD

Subdivision Name | Lot # | Block #

Latitude / Longitude in Decimal Degree (DD): 43.0686 °N -88.937 °W

Method Code: GCD013

SE SE or Govt Lot # | Section: 15 | Township: 7 N | Range: 13 E

2. Well Type Replacement

of previous unique well # constructed in

Reason for replaced or reconstructed well ?: WELL TO REPLACE A WELL PO

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	105

Upper Enlarged Drillhole

Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T		S		BROWN SAND	Surface	61
T		L		BROWN LIMESTONE	61	105

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	T&C SAWHILL STEEL CASING ASTMA53 19.45#/FT HYDRO TESTED 1780 PSI	Surface	65
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

7 ft. below ground surface

10. Pump Test

Pumping level 20 ft. below surface

Pumping at 20 GP M for 9 Hrs.

Pumping Method ?

11. Well Is

30 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
	Surface		

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
JW		06-01-1999
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
MJ		03-03-1999

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		13	Downspout/Yard Hydrant		16
Collector Sewer - San or Storm		32	Shoreline/Pool		74
			Sewer - Building Sanitary		17

Comment:

Variance ID	Variance or Exception Type	Date	Reason
	Separation Distance Variance	02/03/1999	< REQUIRED 50' FROM A BURIED SANITARY COLLECTOR SEWER

Created On: 10-20-1999 Updated On: 09-26-2019 Review Status: