Well Construction Report
WISCONSIN UNIQUE WELL NUMBER MZ632

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: NELSON, ROBERT M	Phone #: (608)423-7518
Mailing Address: N2829 RETZLAFF RD	
City: FORT ATKINSON	State: WI — Zip Code: 53538
County: Jefferson	Co. Permit #: — Notification #: — Completed: 03-15-1999
Well Constructor (Business Name): J F WERNER	Lic. #: 76 — Facility ID # (Public Wells):
Address: N4018 HWY Y, JEFFERSON WI 53549-9801	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #: — Common Well #: — Specific Capacity: 0.7	

1. Well Location

Town of OAKLAND

Fire # (if avail.):

Street Address or Road Name and Number: N2829 RETZLAFF RD

Subdivision Name: — Lot #: — Block #:

Latitude / Longitude in Decimal Degree (DD): 42.9478 °N -88.9764 °W — Method Code: GCD013

SE NE or Govt Lot # — Section: 32 — Township: 6 N — Range: 13 E

2. Well Type New Well

of previous unique well # — constructed in

Reason for replaced or reconstructed well ?: HOME

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	175

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T		S		BROWN SAND	Surface	68
G		Y		GRAY SAND & GRAVEL	68	111
G		L		GRAY LIMESTONE	111	147
Y		N		YELLOW SANDSTONE	147	175

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	T&C SAWHILL STEEL CASING ASTM A53 19.45#/FT HYDRO TESTED 1780 PSI	Surface	113
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

30 ft. below ground surface

10. Pump Test

Pumping level 60 ft. below surface

Pumping at 20 GP M for 18 Hrs.

Pumping Method ?

11. Well Is

24 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
	Surface		

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
JW		06-01-1999
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
MJ		03-16-1999

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		133	Downspout/Yard Hydrant		24
Building Drain - Sanitary		38	Sewer - Building Sanitary		78
Building Overhang		22	Septic or Holding, or POWTS Tank		107

Comment:

Created On: 10-15-1999 Updated On: 09-26-2019 Review Status: