

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				MZ633		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner ERDMAN, DOUG						Phone # (920)568-0871		1. Well Location				Fire # (if avail.)	
Mailing Address N3059 HWY 89						Town of JEFFERSON						Street Address or Road Name and Number N3053 HWY 89	
City JEFFERSON		State WI		Zip Code 53549		Subdivision Name				Lot #		Block #	
County Jefferson		Co. Permit #		Notification #		Completed 03-31-1999		Latitude / Longitude in Decimal Degree (DD) 42.95498 °N -88.84408 °W				Method Code GPS008	
Well Constructor (Business Name) J F WERNER				Lic. # 76		Facility ID # (Public Wells)		NE SE Section Township Range or Govt Lot # 28 6 N 14 E		2. Well Type New Well			
Address N4018 HWY Y JEFFERSON WI 53549-9801				Well Plan Approval #		Approval Date (mm-dd-yyyy)		of previous unique well # constructed in					
Hicap Permanent Well #		Common Well #		Specific Capacity 0.9		Reason for replaced or reconstructed well ? NEW HOME							
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?		Construction Type Drilled							
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology			
6		Surface		236		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...			
								Y S		YELLOW SAND Surface 10			
								A G		COURSE GRAVEL 10 43			
								T Y		BROWN SAND & GRAVEL 43 107			
								G Y		GRAY SAND & GRAVEL 107 130			
								Y S		YELLOW HEAVING SAND 130 157			
								Y Y		YELLOW SAND & GRAVEL 157 236			
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level			
6		T&C SAWHILL STEEL CASING ASTM A53 19.45 LBS/FT HYDRO TESTED 1780 PSI				Surface		236		57 ft. below ground surface			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		11. Well Is			
										16 in. above grade			
7. Grout or Other Sealing Material													
Method													
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		10. Pump Test			
				Surface						Developed ? Yes Disinfected ? Yes Capped ? Yes			
12. Notified Owner of need to fill & seal ?													
Filled & Sealed Well(s) as needed?													
13. Constructor / Supervisory Driller													
JW								Lic #		Date Signed 06-01-1999			
Drill Rig Operator								Lic or Reg #		Date Signed 04-01-1999			
MJ													

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		81	Downspout/Yard Hydrant		15
Building Drain - Sanitary		22	Foundation Drain to Clearwater		16
Building Overhang		13	Sewer - Building Sanitary		27
Clearwater Sump		30	Septic or Holding, or POWTS Tank		52

Comment:

Created On: 10-18-1999

Updated On: 09-23-2022

Review Status: