Well Construction Report
WISCONSIN UNIQUE WELL NUMBER MZ633

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: ERDMAN, DOUG			Phone #: (920)568-0871
Mailing Address: N3059 HWY 89			
City: JEFFERSON	State: WI	Zip Code: 53549	
County: Jefferson	Co. Permit #:	Notification #:	Completed: 03-31-1999

Well Constructor (Business Name): J F WERNER	Lic. #: 76	Facility ID # (Public Wells):	
Address: N4018 HWY Y JEFFERSON WI 53549-9801		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #	Specific Capacity: 0.9	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of JEFFERSON

Fire # (if avail.)

Street Address or Road Name and Number: N3053 HWY 89

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD): 42.95498 °N -88.84408 °W
Method Code: GPS008

NE SE or Govt Lot #	Section: 28	Township: 6 N	Range: 14 E

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
NEW HOME

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	236

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
Y		S		YELLOW SAND	Surface	10
	A	G		COURSE GRAVEL	10	43
T		Y		BROWN SAND & GRAVEL	43	107
G		Y		GRAY SAND & GRAVEL	107	130
Y		S		YELLOW HEAVING SAND	130	157
Y		Y		YELLOW SAND & GRAVEL	157	236

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	T&C SAWHILL STEEL CASING ASTM A53 19.45 LBS/FT HYDRO TESTED 1780 PSI	Surface	236
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material
Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
	Surface		

9. Static Water Level
57 ft. below ground surface

10. Pump Test
Pumping level 80 ft. below surface
Pumping at 20 GP M for 16 Hrs.
Pumping Method ?

11. Well Is
16 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
JW		06-01-1999
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
MJ		04-01-1999

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		81
Building Drain - Sanitary		22
Building Overhang		13
Clearwater Sump		30

Type	Qualifier	Distance
Downspout/Yard Hydrant		15
Foundation Drain to Clearwater		16
Sewer - Building Sanitary		27
Septic or Holding, or POWTS Tank		52

Comment:

Created On: 10-18-1999 Updated On: 09-23-2022 Review Status: