Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ND389

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: C & M FISHER, STUBBENDICKE	Phone #: (608)754-6637
Mailing Address: 325 ARCH ST	
City: JANESVILLE	State: WI Zip Code: 53545
County: Rock	Co. Permit #:	Notification #:	Completed: 05-03-1999
Well Constructor (Business Name): BILL VAN DE YACHT	Lic. #: 37	Facility ID # (Public Wells):
Address: 3671 MONROE RD DE PERE WI 54115-9711	Well Plan Approval #:	Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0.7

1. Well Location

Town of JANESVILLE

Fire # (if avail.):

Street Address or Road Name and Number: 4602 N KATHERINE DR

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)	Method Code
42.7393 °N -89.1249 °W	GCD013

SE NW or Govt Lot #	Section	Township	Range
	7	3 N	12 E

2. Well Type New Well

of previous unique well #: constructed in

Reason for replaced or reconstructed well ?:

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	100

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		X		CLAY SAND	Surface	9
		Y		SAND & GRAVEL	9	60
		X		CLAY & SAND	60	68
		Y		SAND & GRAVEL	68	100

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STD. BLK. PIPE, .280 WALL, WLD. JNTS. A53 SAWHILL	Surface	97
5	RISER PIPE W/PACKER	93	97
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5	#20 SLOTTED STAINLESS	97	100

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		2 S

9. Static Water Level

40 ft. below ground surface

10. Pump Test

Pumping level 70 ft. below surface

Pumping at 20 GP M for 1 Hrs.

Pumping Method ?

11. Well Is

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
JV		05-14-1999
Drill Rig Operator	Lic or Reg #	Date Signed
SUK		05-15-1999

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		224

Type	Qualifier	Distance
Building Overhang		11
Septic or Holding, or POWTS Tank		86

Comment:

Created On: 08-25-1999 Updated On: 12-09-2019 Review Status: