Well Construction Report
WISCONSIN UNIQUE WELL NUMBER NE232

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: TURNIPSEED, ADELL			Phone #: (608)647-4752
Mailing Address: 14737 BERRY HILL RD			
City: RICHLAND CENTER	State: WI	Zip Code: 53581	
County: Richland	Co. Permit #:	Notification #:	Completed: 11-20-2001

Well Constructor (Business Name): DEAN E RICKARD	Lic. #: 481	Facility ID # (Public Wells):	
Address: PO BOX 0499 458 WASLEY ST LINDEN WI 53553-0499		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 5	

3. Well serves 1 # of DWELLING
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of MARSHALL

Fire # (if avail.)

Street Address or Road Name and Number

Subdivision Name	Lot #	Block #	
Latitude / Longitude in Decimal Degree (DD) °N °W			Method Code

NW NW or Govt Lot #	Section: 11	Township: 11 N	Range: 1 W	

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
NEEDED WATER

Construction Type Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	41
6	41	90

Upper Enlarged Drillhole / Lower Open Bedrock

Rotary - Mud Circulation .....
Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Yes Cable-tool Bit 10in. dia... No
Dual Rotary .....
Yes Temp. Outer Casing ____in. dia
Yes Removed? 10depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	I	-	TOPSOIL	Surface	1
-	-	C	-	CLAY	1	20
-	-	H	-	SHALE	20	90

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	SCED 49 18:97 P.E. PITLESS 6.625 O.D. 280 ERW SAWHILL U.S.A.	Surface	41
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method TREMIE GRAVITY

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CEMENT GROUT	Surface	41	29 S

9. Static Water Level
23 ft. below ground surface

10. Pump Test
Pumping level 25 ft. below surface
Pumping at 10 GP M for 2 Hrs.
Pumping Method ?

11. Well Is
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No
NONE

13. Constructor / Supervisory Driller	Lic #	Date Signed
ARH		11-30-2001
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
KN		11-30-2001

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	50
Building Drain - Sanitary	>	8

Type	Qualifier	Distance
Building Overhang	>	2
Sewer - Building Sanitary	>	8
Septic or Holding, or POWTS Tank	>	25

Comment:

Created On: 01-03-2002 Updated On: 01-03-2002 Review Status: