Well Construction Report
WISCONSIN UNIQUE WELL NUMBER NE471

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: GAZDECKI, MIKE & LYNDA			Phone #
Mailing Address: 1605 ELM GROVE RD			
City: NEW BERLIN	State: WI	Zip Code: 53936	
County: Adams	Co. Permit #	Notification #	Completed: 09-08-1999

Well Constructor (Business Name): RAY E FOSTER	Lic. #: 164	Facility ID # (Public Wells)	
Address: 2502 STATE RD 13 ADAMS WI 53910-9739		Well Plan Approval #	
		Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #	Specific Capacity	

3. Well serves 1 # of HOMES
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location

Town of EASTON				Fire # (if avail.): 2529
Street Address or Road Name and Number: COUNTY B				
Subdivision Name: CSM 488			Lot #: 2	Block #
Latitude / Longitude in Decimal Degree (DD): 43.8865 °N -89.7174 °W				Method Code: GCD013
SE	NE	Section: 12	Township: 16 N	Range: 6 E
or Govt Lot #				

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type Jetted

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	6
2	6	63

Upper Enlarged Drillhole / Lower Open Bedrock

Rotary - Mud Circulation .....
Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
	Y			SAND & GRAVEL	Surface	30
	C			CLAY	30	50
A	Y			COARSE SAND & GRAVEL	50	63

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
2	LACLEDE TYPE II ASTM A-589 3.75	Surface	59
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
1.25	CAMPBELL SS 10 SLOT	59	63

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
PITLESS	Surface	6	

9. Static Water Level
15 ft. below ground surface

10. Pump Test
Pumping level 15 ft. below surface
Pumping at 12 GP M for 1 Hrs.
Pumping Method ?

11. Well Is
24 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No
NONE

13. Constructor / Supervisory Driller	Lic #	Date Signed
DSF		09-27-1999
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ?

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		72
Building Overhang		4

Type	Qualifier	Distance
Wastewater Sump		50
Sewer - Building Sanitary		50
Septic or Holding, or POWTS Tank		60

Comment:

Created On: 12-23-1999 Updated On: 05-04-2020 Review Status: