Well Construction Report
WISCONSIN UNIQUE WELL NUMBER NF038

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: HUXHOLD BUILDERS & REALTORS			Phone #: (262)657-7330
Mailing Address: 5300 GREENBAY RD			
City: KENOSHA	State: WI	Zip Code: 53142	
County: Kenosha	Co. Permit #:	Notification #:	Completed: 04-24-2000

Well Constructor (Business Name): WILLIAM J GOHLKE	Lic. #: 693	Facility ID # (Public Wells):	
Address: 19400 38TH ST BRISTOL WI 53104-9740		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 1.3	

1. Well Location

Town of SALEM

Fire # (if avail.):

Street Address or Road Name and Number: 6025 248TH CT

Subdivision Name: PATHWAYS GLENN	Lot #:	Block #:

Latitude / Longitude in Decimal Degree (DD): 42.5819 °N -88.1104 °W				Method Code: GCD013
NE NE or Govt Lot #	Section: 3	Township: 1 N	Range: 20 E	

2. Well Type New Well

of previous unique well #: constructed in:

Reason for replaced or reconstructed well ?:

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
9	Surface	109

Upper Enlarged Drillhole / Lower Open Bedrock

Yes Rotary - Mud Circulation .....
Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T		C		BROWN CLAY	Surface	12
G		C		GREY CLAY	12	56
G		C	P	GREY CLAY HARDPAN	56	65
G		C		GREY CLAY	65	97
G		C	P	GREY CLAY HARDPAN	97	100
		Y		SAND & GRAVEL	100	109

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
5	NEW P.V.C. CERTAINTEED NSF SDR 21 1120-2241	Surface	104
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
		104	109

9. Static Water Level

75 ft. below ground surface

10. Pump Test

Pumping level 90 ft. below surface

Pumping at 20 GP M for 1 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GROUT-WELL DF	Surface	104	10 S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
WFG		04-27-2000
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
TLS		04-26-2000

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Drain - Sanitary		25	Building Overhang		10
			Collector Sewer - San or Storm		85

Comment:

Created On: 10-03-2000 Updated On: 08-23-2019 Review Status: