Well Construction Report
WISCONSIN UNIQUE WELL NUMBER NF062

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: TENUTA, TONY	Phone #: 6977411
Mailing Address: 6310 10TH PL	
City: SOMERS	State: WI — Zip Code: 53171
County: Kenosha	Co. Permit #: — Notification #: — Completed: 12-18-2000
Well Constructor (Business Name): THOMAS SCHULTZ	Lic #: 6643 — Facility ID # (Public Wells):
Address: 4500 18TH ST, KENOSHA WI 54144	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 0.3

1. Well Location

Town of SOMERS

Fire # (if avail.):

Street Address or Road Name and Number: 6310 10TH PL

Subdivision Name: — Lot #: — Block #:

Latitude / Longitude in Decimal Degree (DD): 42.6432 °N -87.8851 °W — Method Code: GCD013

NW SE or Govt Lot #: — Section: 10 — Township: 2 N — Range: 22 E

2. Well Type New Well

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?:

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
9	Surface	116

Upper Enlarged Drillhole — Lower Open Bedrock

Yes — No

Rotary - Mud Circulation .....
Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	-	C	P	BROWN CLAY HARDPAN	Surface	12
G	-	C	-	GREY CLAY	12	50
G	-	C	P	GREY CLAY HARDPAN	50	72
G	-	C	-	GREY CLAY	72	80
G	-	C	P	GREY CLAY HARD PAN	80	110
-	-	Y	-	SAND & GRAVEL	110	116

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
5	NEW PVC CERTAINEED	Surface	111
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5	PVC ENVIRONMENTAL	111	116

7. Grout or Other Sealing Material

Method PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GROUT-WELL DF	Surface	111	11 S

9. Static Water Level

40 ft. below ground surface

10. Pump Test

Pumping level 80 ft. below surface

Pumping at 12 GP M for 1 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
TLS		12-20-2000
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Drain - Sanitary		100	Collector Sewer - San or Storm		150
Building Overhang		48	Foundation Drain to Sewer		110
			Sewer - Building Sanitary		85

Comment:

Created On: 06-27-2001 Updated On: 08-23-2019 Review Status: