

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				NF062		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A	
Property Owner TENUTA, TONY Phone # 6977411						1. Well Location				Fire # (if avail.)	
Mailing Address 6310 10TH PL						Town of SOMERS				Street Address or Road Name and Number 6310 10TH PL	
City SOMERS		State WI		Zip Code 53171		Subdivision Name				Lot #	Block #
County Kenosha	Co. Permit #	Notification #		Completed 12-18-2000		Latitude / Longitude in Decimal Degree (DD)				Method Code	
Well Constructor (Business Name) THOMAS SCHULTZ				Lic. # 6643	Facility ID # (Public Wells) Well Plan Approval #		42.6432 °N -87.8851 °W		GCD013		
							NW SE Section Township Range or Govt Lot # 10 2 N 22 E		Approval Date (mm-dd-yyyy)		
Address 4500 18TH ST KENOSHA WI 54144				Hicap Permanent Well # Common Well # Specific Capacity 0.3		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled					
Hicap Permanent Well # Common Well # Specific Capacity 0.3											
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?							
4. Potential Contamination Sources - ON REVERSE SIDE											
5. Drillhole Dimensions and Construction Method											
Dia. (in.)	From (ft.)	To (ft.)	Upper Enlarged Drillhole				Lower Open Bedrock				
9	Surface	116	Yes Rotary - Mud Circulation No Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)								
8. Geology											
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)			
T	-	C	P	BROWN CLAY HARDPAN	Surface	12					
G	-	C	-	GREY CLAY	12	50					
G	-	C	P	GREY CLAY HARDPAN	50	72					
G	-	C	-	GREY CLAY	72	80					
G	-	C	P	GREY CLAY HARD PAN	80	110					
-	-	Y	-	SAND & GRAVEL	110	116					
6. Casing, Liner, Screen											
Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)	To (ft.)					
5	NEW PVC CERTAINEED				Surface	111					
Dia. (in.)	Screen type, material & slot size				From (ft.)	To (ft.)					
5	PVC ENVIRONMENTAL				111	116					
7. Grout or Other Sealing Material											
Method PUMPED											
Kind of Sealing Material		From (ft.)	To (ft.)	# Sacks Cement							
GROUT-WELL DF		Surface	111	11 S							
9. Static Water Level											
40 ft. below ground surface											
10. Pump Test											
Pumping level 80 ft. below surface Pumping at 12 GP M for 1 Hrs. Pumping Method ?											
11. Well Is											
12 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes											
12. Notified Owner of need to fill & seal ?											
Filled & Sealed Well(s) as needed?											
13. Constructor / Supervisory Driller											
Lic # Date Signed TLS 12-20-2000											
Drill Rig Operator											
Lic or Reg # Date Signed											

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Drain - Sanitary		100	Collector Sewer - San or Storm		150
Building Overhang		48	Foundation Drain to Sewer		110
			Sewer - Building Sanitary		85

Comment:

Created On: 06-27-2001

Updated On: 08-23-2019

Review Status: