Well Construction Report
WISCONSIN UNIQUE WELL NUMBER NF090

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: WAGNER, ROBERT	Phone #: (847)877-1548
Mailing Address: 10359 187TH AVE	
City: BRISTOL	State: WI — Zip Code: 53104
County: Kenosha	Co. Permit #: — Notification #: — Completed: 09-25-2001
Well Constructor (Business Name): THOMAS SCHULTZ	Lic. #: 6643 — Facility ID # (Public Wells):
Address: 4500 18TH ST, KENOSHA WI 54144	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 0.1

1. Well Location

Town of BRISTOL

Fire # (if avail.):

Street Address or Road Name and Number: 10359 187TH AVE

Subdivision Name: — Lot #: — Block #:

Latitude / Longitude in Decimal Degree (DD): 42.5247 °N -88.0327 °W — Method Code: GCD013

SE SE or Govt Lot # — Section: 20 — Township: 1 N — Range: 21 E

2. Well Type Replacement

of previous unique well # — constructed in

Reason for replaced or reconstructed well ?: 2 1/2IN POINT DRY

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
9	Surface	198

Upper Enlarged Drillhole — Lower Open Bedrock

Yes — Rotary - Mud Circulation ..... — No

Rotary - Air .....

Rotary - Air & Foam .....

Drill-Through Casing Hammer

Reverse Rotary

Cable-tool Bit ____in. dia...

Dual Rotary .....

Temp. Outer Casing ____in. dia

Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	I	-	TOPSOIL	Surface	2
T	-	C	-	BROWN CLAY	2	10
G	-	C	-	GREY CLAY	10	74
G	-	C	P	GREY CLAY HARD PAN	74	190
-	-	Y	-	SAND & GRAVEL	190	198

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
5	NEW P.V.C. CERTAINTEED 1120 SDR21 2241 PND	Surface	193
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5	P.V.C. ENVIROMENTAL	193	198

7. Grout or Other Sealing Material

Method PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GROUT WELL DF	Surface	193	19 S

9. Static Water Level

45 ft. below ground surface

10. Pump Test

Pumping level 100 ft. below surface

Pumping at 3 GP M for 24 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
TLS		09-26-2001
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Drain - Sanitary		75	Collector Sewer - San or Storm		150
Building Overhang		10	Sewer - Building Sanitary		70

Comment:

Created On: 10-31-2001 Updated On: 08-23-2019 Review Status: