

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				NF090		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A				
Property Owner WAGNER, ROBERT						Phone # (847)877-1548		1. Well Location				Fire # (if avail.)		
Mailing Address 10359 187TH AVE						Town of BRISTOL						Street Address or Road Name and Number 10359 187TH AVE		
City BRISTOL			State WI		Zip Code 53104			Subdivision Name			Lot #		Block #	
County Kenosha		Co. Permit #		Notification #		Completed 09-25-2001		Latitude / Longitude in Decimal Degree (DD) 42.5247 °N -88.0327 °W			Method Code GCD013			
Well Constructor (Business Name) THOMAS SCHULTZ				Lic. # 6643		Facility ID # (Public Wells)		SE SE Section Township Range or Govt Lot # 20 1 N 21 E		2. Well Type Replacement				
Address 4500 18TH ST KENOSHA WI 54144				Well Plan Approval #		Approval Date (mm-dd-yyyy)		of previous unique well # constructed in						
Hicap Permanent Well #			Common Well #		Specific Capacity 0.1		Reason for replaced or reconstructed well ? 2 1/2IN POINT DRY							
3. Well serves 1 # of Private, potable				Hicap Well ? No		Hicap Property ? No		Construction Type Drilled						
Heat Exchange ___ # of drillholes				Hicap Potable ?										
4. Potential Contamination Sources - ON REVERSE SIDE														
5. Drillhole Dimensions and Construction Method														
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole			Lower Open Bedrock					
9		Surface		198		Yes Rotary - Mud Circulation No Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)								
8. Geology														
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)						
- - I -		TOPSOIL				Surface		2						
T - C -		BROWN CLAY				2		10						
G - C -		GREY CLAY				10		74						
G - C P		GREY CLAY HARD PAN				74		190						
- - Y -		SAND & GRAVEL				190		198						
6. Casing, Liner, Screen														
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)						
5		NEW P.V.C. CERTAINTED 1120 SDR21 2241 PND				Surface		193						
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)						
5		P.V.C. ENVIROMENTAL				193		198						
7. Grout or Other Sealing Material														
Method PUMPED														
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement						
GROUT WELL DF				Surface		193		19 S						
9. Static Water Level														
45 ft. below ground surface														
10. Pump Test														
Pumping level 100 ft. below surface														
Pumping at 3 GP M for 24 Hrs.														
Pumping Method ?														
11. Well Is														
12 in. above grade														
Developed ? Yes														
Disinfected ? Yes														
Capped ? Yes														
12. Notified Owner of need to fill & seal ?														
Filled & Sealed Well(s) as needed? Yes														
13. Constructor / Supervisory Driller														
Lic #				Date Signed										
TLS				09-26-2001										
Drill Rig Operator				Lic or Reg #		Date Signed								

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		10	Sewer - Building Sanitary		70
Building Drain - Sanitary		75	Collector Sewer - San or Storm		150

Comment:

Created On: 10-31-2001

Updated On: 08-23-2019

Review Status: