Well Construction Report
WISCONSIN UNIQUE WELL NUMBER NF091

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: ZOERNER, MIKE	Phone #: (262)818-5442
Mailing Address: 10902 75TH ST APT 10	
City: KENOSHA	State: WI — Zip Code: 53142
County: Kenosha	Co. Permit #: — Notification #: — Completed: 09-26-2001
Well Constructor (Business Name): THOMAS SCHULTZ	Lic. #: 6643 — Facility ID # (Public Wells):
Address: 4500 18TH ST KENOSHA WI 54144	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 0.2

1. Well Location

Fire # (if avail.):

Town of SALEM

Street Address or Road Name and Number: 6350 218TH AVE (ZOERNER)

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)	Method Code
42.5772 °N -88.0742 °W	GCD013

SE	NE	Section	Township	Range
or Govt Lot #		1	1 N	20 E

2. Well Type New Well

of previous unique well # — constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
9	Surface	96

Upper Enlarged Drillhole — Lower Open Bedrock

Yes — Rotary - Mud Circulation ..... — No

Rotary - Air .....

Rotary - Air & Foam .....

Drill-Through Casing Hammer

Reverse Rotary

Cable-tool Bit ____in. dia...

Dual Rotary .....

Temp. Outer Casing ____in. dia

Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	-	C	-	BROWN CLAY	Surface	14
G	-	C	-	GREY CLAY	14	32
G	-	C	P	GREY CLAY HARDPAN	32	90
-	-	Y	-	SAND & GRAVEL	90	96

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
5	NEW P.V.C. CERTAINTEED NSF 2241 1120-SDR21	Surface	91
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5	ID P.V.C. ENVIROMENTAL	91	96

7. Grout or Other Sealing Material

Method PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GROUT WELL DF	Surface	91	9 S

9. Static Water Level

30 ft. below ground surface

10. Pump Test

Pumping level 80 ft. below surface

Pumping at 12 GP M for 1 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
TLS		10-04-2001
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Drain - Sanitary		60	Sewer - Building Sanitary		80
Clearwater Sump		80	Septic or Holding, or POWTS Tank		155

Comment:

Created On: 10-31-2001 Updated On: 08-23-2019 Review Status: