

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				NF091		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner ZOERNER, MIKE						Phone # (262)818-5442		1. Well Location				Fire # (if avail.)	
Mailing Address 10902 75TH ST APT 10						Town of SALEM						Street Address or Road Name and Number 6350 218TH AVE (ZOERNER)	
City KENOSHA		State WI		Zip Code 53142		Subdivision Name				Lot #		Block #	
County Kenosha		Co. Permit #		Notification #		Completed 09-26-2001		Latitude / Longitude in Decimal Degree (DD) 42.5772 °N -88.0742 °W				Method Code GCD013	
Well Constructor (Business Name) THOMAS SCHULTZ				Lic. # 6643		Facility ID # (Public Wells)		SE NE Section Township Range or Govt Lot # 1 1 N 20 E		2. Well Type New Well			
Address 4500 18TH ST KENOSHA WI 54144				Well Plan Approval #		Approval Date (mm-dd-yyyy)		of previous unique well # constructed in					
Hicap Permanent Well #		Common Well #		Specific Capacity 0.2		Reason for replaced or reconstructed well ?							
3. Well serves 1 # of Private, potable				Hicap Well ? No		Hicap Property ? No		Construction Type Drilled					
Heat Exchange ___ # of drillholes				Hicap Potable ?									
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole			Lower Open Bedrock				
9		Surface		96		Yes Rotary - Mud Circulation No							
						Rotary - Air							
						Rotary - Air & Foam							
						Drill-Through Casing Hammer							
						Reverse Rotary							
						Cable-tool Bit ___ in. dia...							
						Dual Rotary							
						Temp. Outer Casing ___ in. dia							
						Removed? ___ depth ft. (If NO explain on back side)							
8. Geology													
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)					
T - C -		BROWN CLAY				Surface		14					
G - C -		GREY CLAY				14		32					
G - C P		GREY CLAY HARDPAN				32		90					
- - Y -		SAND & GRAVEL				90		96					
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)					
5		NEW P.V.C. CERTAINTED NSF 2241 1120-SDR21				Surface		91					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)					
5		ID P.V.C. ENVIROMENTAL				91		96					
7. Grout or Other Sealing Material													
Method PUMPED													
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement					
GROUT WELL DF				Surface		91		9 S					
9. Static Water Level													
30 ft. below ground surface													
10. Pump Test													
Pumping level 80 ft. below surface													
Pumping at 12 GP M for 1 Hrs.													
Pumping Method ?													
11. Well Is													
12 in. above grade													
Developed ? Yes													
Disinfected ? Yes													
Capped ? Yes													
12. Notified Owner of need to fill & seal ?													
Filled & Sealed Well(s) as needed?													
13. Constructor / Supervisory Driller								Lic #		Date Signed			
TLS										10-04-2001			
Drill Rig Operator								Lic or Reg #		Date Signed			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Drain - Sanitary		60	Sewer - Building Sanitary		80
Clearwater Sump		80	Septic or Holding, or POWTS Tank		155

Comment:

Created On: 10-31-2001

Updated On: 08-23-2019

Review Status: