

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				NM862		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner COOKE, TOMAS & KIM						Phone # (608)592-7529		1. Well Location				Fire # (if avail.)	
Mailing Address N2462 HWY V						City of LODI							
City LODI						State WI		Zip Code 53555					
County Columbia		Co. Permit #		Notification #		Completed 08-09-1999		Subdivision Name BACK 40				Lot # Block #	
Well Constructor (Business Name) BRADLEY S WEBSTER				Lic. # 614		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code	
Address N2323 PINE HOLLOW RD POYNETTE WI 53955-9620				Well Plan Approval #		Approval Date (mm-dd-yyyy)		SW SW Section Township Range or Govt Lot # 9 10 N 8 E		2. Well Type New Well			
Hicap Permanent Well #		Common Well #		Specific Capacity 1.7		Reason for replaced or reconstructed well ?							
3. Well serves 1 # of Private, potable				Hicap Well ? No									
Heat Exchange ___ # of drillholes				Hicap Property ? No									
				Hicap Potable ?		Construction Type Drilled							
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole			Lower Open Bedrock				
6		Surface		86		Rotary - Mud Circulation							
						<u>Yes</u> Rotary - Air							
						Rotary - Air & Foam							
						Drill-Through Casing Hammer							
						Reverse Rotary							
						Cable-tool Bit ___ in. dia...							
						Dual Rotary							
						Temp. Outer Casing ___ in. dia							
						Removed? ___ depth ft. (If NO explain on back side)							
8. Geology													
Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...			From (ft.)			To (ft.)				
Q X G			SAND, ROCK, & CLAY (CAVING)			Surface			40				
S			SAND			40			45				
S N			WEAK/SOFT SANDSTONE			45			66				
H N			FIRM SANDSTONE			66			86				
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)					
6		SAWHILL PE .280 WALL A53B				Surface		66					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)					
7. Grout or Other Sealing Material													
Method													
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement					
MOUNDED BENTONITE				Surface									
9. Static Water Level													
18 ft. below ground surface													
10. Pump Test													
Pumping level 25 ft. below surface													
Pumping at 12 GP M for 2 Hrs.													
Pumping Method ?													
11. Well Is													
20 in. above grade													
Developed ? Yes													
Disinfected ? Yes													
Capped ? Yes													
12. Notified Owner of need to fill & seal ?													
Filled & Sealed Well(s) as needed? No													
NONE ON PROPERTY													
13. Constructor / Supervisory Driller													
Lic #				Date Signed									
BW				09-10-1999									
Drill Rig Operator				Lic or Reg #				Date Signed					
RW				08-09-1999									

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		25	Foundation Drain to Clearwater		40
Clearwater Sump		60	Landfill	>	1200

Comment:

Created On: 02-22-2000

Updated On: 02-22-2000

Review Status: