Well Construction Report
WISCONSIN UNIQUE WELL NUMBER NM862

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: COOKE, TOMAS & KIM	Phone #: (608)592-7529
Mailing Address: N2462 HWY V	
City: LODI	State: WI Zip Code: 53555
County: Columbia	Co. Permit #:	Notification #:	Completed: 08-09-1999

1. Well Location
City of LODI
Fire # (if avail.)
Street Address or Road Name and Number: REAL SHORT RD
Subdivision Name: BACK 40 | Lot # | Block #

Well Constructor (Business Name): BRADLEY S WEBSTER	Lic. #: 614	Facility ID # (Public Wells)	Latitude / Longitude in Decimal Degree (DD): °N °W	Method Code
Address: N2323 PINE HOLLOW RD, POYNETTE WI 53955-9620		Well Plan Approval #	SW SW or Govt Lot #	Section: 9	Township: 10 N	Range: 8 E
		Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #	Specific Capacity: 1.7	

2. Well Type New Well
of previous unique well # constructed in
Reason for replaced or reconstructed well ?

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes
Hicap Well ? No
Hicap Property ? No
Hicap Potable ?
Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	86

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes — Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
Q	X	G	SAND, ROCK, & CLAY (CAVING)	Surface	40
	S		SAND	40	45
S	N		WEAK/SOFT SANDSTONE	45	66
H	N		FIRM SANDSTONE	66	86

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	SAWHILL PE .280 WALL A53B	Surface	66
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level
18 ft. below ground surface

10. Pump Test
Pumping level 25 ft. below surface
Pumping at 12 GP M for 2 Hrs.
Pumping Method ?

11. Well Is
20 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
MOUNDED BENTONITE	Surface		

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed? No
NONE ON PROPERTY

13. Constructor / Supervisory Driller	Lic #	Date Signed
BW		09-10-1999
Drill Rig Operator	Lic or Reg #	Date Signed
RW		08-09-1999

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		25	Foundation Drain to Clearwater		40
Clearwater Sump		60	Landfill	>	1200

Comment:

Created On: 02-22-2000 Updated On: 02-22-2000 Review Status: