

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				NN387		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner WEBB, ROBERT						Phone # (920)526-3504		1. Well Location				Fire # (if avail.)					
Mailing Address N5328W CTY A						Town of GREENBUSH						N5228					
City PLYMOUTH						State WI		Zip Code 53073				Street Address or Road Name and Number					
County Sheboygan						Co. Permit #		Notification #		Completed 11-13-2000		Subdivision Name		Lot #		Block #	
Well Constructor (Business Name) DENNIS R LEFEBER						Lic. # 434		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.7297 °N -88.0831 °W		Method Code GCD013			
Address W2593 CNTY Q MALONE WI 53049-1242						Well Plan Approval #				SW SW Section Township Range or Govt Lot # 26 15 N 20 E		2. Well Type Replacement of previous unique well # constructed in Reason for replaced or reconstructed well ? NOT ENOUGH GPM					
						Approval Date (mm-dd-yyyy)											
Hicap Permanent Well #				Common Well #		Specific Capacity 2				Construction Type Drilled							
3. Well serves 1 # of BARN Private, potable						Hicap Well ? No Hicap Property ? No											
Heat Exchange ___ # of drillholes						Hicap Potable ?											
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method																	
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock							
6		Surface		139		Rotary - Mud Circulation <u>Yes</u> Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)											
8. Geology																	
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)									
		Y		GRAVEL & SAND		Surface		35									
		Z		GRAVEL & CLAY		35		115									
		G		GRAVEL		115		139									
6. Casing, Liner, Screen																	
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)									
6		ASTM A53 WELDED JOINTS IPSCO				Surface		139									
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)									
7. Grout or Other Sealing Material																	
Method MOUNDED																	
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement											
GRANULAR BENTONITE		Surface		139		4 S											
9. Static Water Level																	
75 ft. below ground surface																	
10. Pump Test																	
Pumping level 85 ft. below surface																	
Pumping at 20 GP M for 1 Hrs.																	
Pumping Method ?																	
11. Well Is																	
32 in. above grade																	
Developed ? Yes																	
Disinfected ? Yes																	
Capped ? Yes																	
12. Notified Owner of need to fill & seal ?																	
Filled & Sealed Well(s) as needed? Yes																	
13. Constructor / Supervisory Driller																	
Lic #		Date Signed															
Drill Rig Operator		Lic or Reg #		Date Signed													
DS																	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		80	Sewer - Building Sanitary		63
Manure Hopper or Reception Tank - Liquid Tight		125	Animal Barn Pen		53
Building Overhang		28	Animal Yard - Include Hutches		52
Downspout/Yard Hydrant		35	Septic or Holding, or POWTS Tank		75

Comment:

Created On: 03-05-2001

Updated On: 10-09-2019

Review Status: