Well Construction Report
WISCONSIN UNIQUE WELL NUMBER NN387

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: WEBB, ROBERT	Phone #: (920)526-3504
Mailing Address: N5328W CTY A	
City: PLYMOUTH	State: WI — Zip Code: 53073
County: Sheboygan	Co. Permit #: — Notification #: — Completed: 11-13-2000
Well Constructor (Business Name): DENNIS R LEFEBER	Lic. #: 434 — Facility ID # (Public Wells):
Address: W2593 CNTY Q, MALONE WI 53049-1242	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 2

1. Well Location

Town of GREENBUSH	Fire # (if avail.): N5228
Street Address or Road Name and Number: N5228W CTY A	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 43.7297 °N -88.0831 °W	Method Code: GCD013
SW SW or Govt Lot #: — Section: 26 — Township: 15 N — Range: 20 E	

2. Well Type Replacement
of previous unique well #: — constructed in:
Reason for replaced or reconstructed well ?: NOT ENOUGH GPM
Construction Type: Drilled

3. Well serves 1 # of BARN
Private,potable
Heat Exchange____# of drillholes
Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	139

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes — Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
Y	GRAVEL & SAND	Surface	35
Z	GRAVEL & CLAY	35	115
G	GRAVEL	115	139

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	ASTM A53 WELDED JOINTS IPSCO	Surface	139
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method: MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	139	4 S

9. Static Water Level
75 ft. below ground surface

10. Pump Test
Pumping level 85 ft. below surface
Pumping at 20 GP M for 1 Hrs.
Pumping Method ?

11. Well Is
32 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
DS		

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		80
Manure Hopper or Reception Tank - Liquid Tight		125
Building Overhang		28
Downspout/Yard Hydrant		35

Type	Qualifier	Distance
Sewer - Building Sanitary		63
Animal Barn Pen		53
Animal Yard - Include Hutches		52
Septic or Holding, or POWTS Tank		75

Comment:

Created On: 03-05-2001 Updated On: 10-09-2019 Review Status: