

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				NN434		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner MOSES, ELSWORTH						Phone # (715)479-7437		1. Well Location				Fire # (if avail.)	
Mailing Address 1636 LIGHT HOUSE LOD						Town of THREE LAKES						1636	
City CLEARWATER LAKE						State WI		Zip Code 54521				Street Address or Road Name and Number 1636 LIGHT HOUSE LODGE RD	
County Oneida		Co. Permit #		Notification #		Completed 02-13-2002		Subdivision Name				Lot # Block #	
Well Constructor (Business Name) KLISS PLBG HTG & SEPTIC SERV INC				Lic. # 6341		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 45.84771 °N -89.15325 °W				Method Code GPS008	
Address 1030 HWY 455 EAGLE RIVER WI 54521				Well Plan Approval #		Section 19		Township 39 N		Range 11 E			
				Approval Date (mm-dd-yyyy)		or Govt Lot # 1							
Hicap Permanent Well #		Common Well #		Specific Capacity		2. Well Type Replacement XG657 replaces this well of previous unique well # constructed in							
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes						Hicap Well ? No		Reason for replaced or reconstructed well ? PLUGGED POINT Construction Type Driven Point					
						Hicap Property ? No							
						Hicap Potable ?							
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
				Upper Enlarged Drillhole				Lower Open Bedrock					
				Rotary - Mud Circulation									
				Rotary - Air									
				Rotary - Air & Foam									
				Drill-Through Casing Hammer									
				Reverse Rotary									
				Cable-tool Bit ___ in. dia...									
				Dual Rotary									
				Temp. Outer Casing ___ in. dia									
6. Casing, Liner, Screen						Removed? ___ depth ft. (If NO explain on back side)							
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)					
2.5		WHITE WATER PITLESS				Surface		5					
2		R&D GALV ASTM 589-F				5		42					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)					
2		MIDWEST GALV POINT 60#				42		46					
7. Grout or Other Sealing Material													
Method POINT													
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement					
				Surface									
8. Geology													
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)					
- - Y -		SAND & GRAVEL				Surface		46					
9. Static Water Level						11. Well Is							
28 ft. below ground surface						12 in. above grade							
10. Pump Test						Developed ? Yes							
Pumping level ___ ft. below surface						Disinfected ? Yes							
Pumping at 7 GP M for 1 Hrs.						Capped ? Yes							
Pumping Method ?													
12. Notified Owner of need to fill & seal ?													
Filled & Sealed Well(s) as needed? Yes													
13. Constructor / Supervisory Driller						Lic #		Date Signed					
LK								02-19-2002					
Drill Rig Operator						Lic or Reg #		Date Signed					
LN								02-19-2002					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		60	Shoreline/Pool		100
Building Drain - Sanitary		25	Nonconforming Pit or Alcove		30
Building Overhang		5	Sewer - Building Sanitary		25
			Septic or Holding, or POWTS Tank		35

Comment:

Abandonment Type	Abandonment Date	Procedure	Reason
	11/05/2013	NEAT CEMENT GROUT 0-46' 1 1/2 SACKS	NEW WELL

Created On: 03-14-2002

Updated On: 09-23-2022

Review Status: