

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				NN982		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A											
Property Owner GIRAND, JOHN						Phone # (219)663-9220		1. Well Location				Fire # (if avail.)									
Mailing Address PO BOX 353						Town of DRAPER						Street Address or Road Name and Number									
City CROWN POINT				State IN		Zip Code 46307															
County		Co. Permit #		Notification #		Completed 08-24-1999		Subdivision Name				Lot #		Block #							
Sawyer						Well Constructor (Business Name)						Lic. #		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD)				Method Code	
TIPLER WELL DRILLING INC						55		Well Plan Approval #						°N		°W		NE NE Section Township Range or Govt Lot # 19 40 N 4 W			
Address PO BOX 34 LAKEWOOD WI 54138-0034						Approval Date (mm-dd-yyyy)															
Hicap Permanent Well #				Common Well #		Specific Capacity 0.4						2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled									
3. Well serves 1 # of HOME						Hicap Well ? No															
Private, potable						Hicap Property ? No															
Heat Exchange ___ # of drillholes						Hicap Potable ?						4. Potential Contamination Sources - ON REVERSE SIDE									
5. Drillhole Dimensions and Construction Method																8. Geology					
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole						Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
7.75		Surface		62		Yes Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)						S		SAND		Surface		10			
												Y C		CLAYED SAND & GRAVEL		10		20			
												Y C		ROCKS SAND & GRAVEL		20		40			
												Y C		CLAYED SAND & GRAVEL		40		46			
												Y		SAND & GRAVEL		46		62			
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is					
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		8 ft. below ground surface				14 in. above grade							
4		EAGLE PVC 1120 SDR 21 200 PSI 73 ASTM D2241				Surface		59		10. Pump Test				Developed ? Yes							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 32 ft. below surface				Disinfected ? Yes							
4		18 SLOT STAINLESS				59		62		Pumping at 10 GP M for 1 Hrs.				Capped ? Yes							
7. Grout or Other Sealing Material												Pumping Method ?				Filled & Sealed Well(s) as needed? No CABIN					
Method												12. Notified Owner of need to fill & seal ?									
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		13. Constructor / Supervisory Driller				Lic #		Date Signed					
DRILL CUTTINGS				Surface		57		TB				TB		08-25-1999							
								Drill Rig Operator				Lic or Reg #		Date Signed							
								TB				TB		08-25-1999							

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		55	Building Overhang		10
			Septic or Holding, or POWTS Tank		35

Comment:

Created On: 12-16-1999

Updated On: 12-16-1999

Review Status: