Well Construction Report
WISCONSIN UNIQUE WELL NUMBER NN982

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: GIRAND, JOHN	Phone #: (219)663-9220
Mailing Address: PO BOX 353	
City: CROWN POINT	State: IN — Zip Code: 46307
County: Sawyer	Co. Permit #: — Notification #: — Completed: 08-24-1999
Well Constructor (Business Name): TIPLER WELL DRILLING INC	Lic #: 55 — Facility ID # (Public Wells):
Address: PO BOX 34, LAKEWOOD WI 54138-0034	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 0.4

1. Well Location

Town of DRAPER

Fire # (if avail.):

Street Address or Road Name and Number:

Subdivision Name: — Lot #: — Block #:

Latitude / Longitude in Decimal Degree (DD): °N °W — Method Code:

NE	NE	Section	Township	Range
or Govt Lot #		19	40 N	4 W

2. Well Type New Well

of previous unique well #: constructed in:

Reason for replaced or reconstructed well ?:

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?:

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
7.75	Surface	62

Upper Enlarged Drillhole — Lower Open Bedrock

Yes Rotary - Mud Circulation .....

Rotary - Air .....

Rotary - Air & Foam .....

Drill-Through Casing Hammer

Reverse Rotary

Cable-tool Bit ____in. dia...

Dual Rotary .....

Temp. Outer Casing ____in. dia

Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		S		SAND	Surface	10
		Y	C	CLAYED SAND & GRAVEL	10	20
		Y	C	ROCKS SAND & GRAVEL	20	40
		Y	C	CLAYED SAND & GRAVEL	40	46
		Y		SAND & GRAVEL	46	62

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	EAGLE PVC 1120 SDR 21 200 PSI 73 ASTM D2241	Surface	59
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
4	18 SLOT STAINLESS	59	62

9. Static Water Level

8 ft. below ground surface

10. Pump Test

Pumping level 32 ft. below surface

Pumping at 10 GP M for 1 Hrs.

Pumping Method ?:

11. Well Is

14 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method:

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
DRILL CUTTINGS	Surface	57	

12. Notified Owner of need to fill & seal ?:

Filled & Sealed Well(s) as needed? No

CABIN

13. Constructor / Supervisory Driller	Lic #	Date Signed
TB		08-25-1999
Drill Rig Operator	Lic or Reg #	Date Signed
TB		08-25-1999

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		55	Building Overhang		10
			Septic or Holding, or POWTS Tank		35

Comment:

Created On: 12-16-1999 Updated On: 12-16-1999 Review Status: