Well Construction Report
WISCONSIN UNIQUE WELL NUMBER NP234

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: DVORAK, RICHARD	Phone #: (920)434-9561
Mailing Address: 2372 SKYLINE PINES D	
City: GREEN BAY	State: WI — Zip Code: 54313
County: Oconto	Co. Permit #: — Notification #: — Completed: 12-07-1999

1. Well Location

Town of TOWNSEND

Fire # (if avail.):

Street Address or Road Name and Number: 16567 WHITE PINE

Subdivision Name: — Lot #: — Block #:

Well Constructor (Business Name): ALLEN D TAMM	Lic. #: 53
Facility ID # (Public Wells):	
Well Plan Approval #:	
Address: PO BOX 34 LAKEWOOD WI 54138	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 0.2	

Latitude / Longitude in Decimal Degree (DD): 45.2774 °N -88.5812 °W

Method Code: GCD013

SE or Govt Lot #	SE	Section: 2	Township: 32 N	Range: 15 E

2. Well Type New Well

of previous unique well # — constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	85
6	85	107

Upper Enlarged Drillhole — Lower Open Bedrock

Yes Rotary - Mud Circulation .....

Rotary - Air .....

Rotary - Air & Foam .....

Drill-Through Casing Hammer

Reverse Rotary

Cable-tool Bit ____in. dia...

Dual Rotary .....

Temp. Outer Casing ____in. dia

Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		Y		SAND, GRAVEL	Surface	15
		Y	G	SAND GRAVEL BOULDERS	15	85
		Y		SAND GRAVEL	85	107

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	ASTM A-53 GR B SAWHILL TUBULAR WELDED JOINT WT 18.97 PER FT	Surface	102
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
4	STAINLESS 12 SLOT	102	107

9. Static Water Level

40 ft. below ground surface

10. Pump Test

Pumping level 90 ft. below surface

Pumping at 10 GP M for 4 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
DRILLING MUD	Surface	102	

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
AF		02-14-2000
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
MB		02-14-2000

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		50	Septic or Holding, or POWTS Tank		25

Comment:

Created On: 03-28-2000 Updated On: 11-15-2019 Review Status: