

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				NP247		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A																					
Property Owner ZUEGE, ROY						Phone # (920)722-6504		1. Well Location				Fire # (if avail.)																			
Mailing Address 1176 WOODGATE LN						Town of LONG LAKE						Street Address or Road Name and Number FAY LK LOT 69																			
City NEENAH				State WI		Zip Code 54956																									
County Florence		Co. Permit #		Notification #		Completed 12-01-1999		Subdivision Name				Lot #		Block #																	
Well Constructor (Business Name) ALLEN D TAMM				Lic. # 53		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD)				Method Code																	
Address PO BOX 34 LAKEWOOD WI 54138				Well Plan Approval #				SE SE Section Township Range or Govt Lot # 8 39 N 15 E		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled																					
				Approval Date (mm-dd-yyyy)																											
Hicap Permanent Well #				Common Well #		Specific Capacity 0.3				3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes																					
Hicap Well ? No Hicap Property ? No Hicap Potable ?				Heat Exchange ___ # of drillholes																											
4. Potential Contamination Sources - ON REVERSE SIDE																															
5. Drillhole Dimensions and Construction Method												8. Geology																			
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)													
10		Surface		70		Yes Rotary - Mud Circulation				Rotary - Air		Rotary - Air & Foam		Drill-Through Casing Hammer		Reverse Rotary		Cable-tool Bit ___ in. dia...		Dual Rotary		Temp. Outer Casing ___ in. dia		Removed? ___ depth ft. (If NO explain on back side)		S SAND Surface 10		G G GRAVEL BOULDERS 10 70		Y SAND GRAVEL 70 85	
6		70		85		Rotary - Air				Rotary - Air & Foam		Drill-Through Casing Hammer		Reverse Rotary		Cable-tool Bit ___ in. dia...		Dual Rotary		Temp. Outer Casing ___ in. dia		Removed? ___ depth ft. (If NO explain on back side)		S SAND Surface 10		G G GRAVEL BOULDERS 10 70		Y SAND GRAVEL 70 85			
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		30 ft. below ground surface				12 in. above grade																	
6		ASTM A-53 GR B SAWHILL TUBULAR WELDED JOINT WT 18.97 PER FT				Surface		85		10. Pump Test				Developed ? Yes																	
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 70 ft. below surface				Disinfected ? Yes																	
Pumping at 10 GP M for 4 Hrs.		Pumping Method ?				Capped ? Yes				12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? Yes																					
7. Grout or Other Sealing Material		Method				13. Constructor / Supervisory Driller								Lic #		Date Signed															
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement		AT				02-16-2000																			
DRILLING MUD		Surface		85		Drill Rig Operator		Lic or Reg #		Date Signed																					
MB		02-16-2000		Date Signed		02-16-2000		Date Signed																							

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		50	Building Overhang		20
			Septic or Holding, or POWTS Tank		25

Comment:

Created On: 03-28-2000

Updated On: 03-28-2000

Review Status: