

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				NR039		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A				
Property Owner GRASS, JAMES						Phone # (715)453-2015		1. Well Location				Fire # (if avail.)		
Mailing Address 1708 N 4TH ST						Town of BRADLEY						Street Address or Road Name and Number DEER LAKE RD		
City TOMAHAWK				State WI		Zip Code 54487								
County Lincoln		Co. Permit #		Notification #		Completed 01-07-2000		Subdivision Name PINEWOOD			Lot #		Block #	
Well Constructor (Business Name) MARVIN HOLZEM				Lic. # 637		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD)			Method Code			
Address N9899 HWY 23 WISCONSIN DELLS WI 53965				Well Plan Approval #		Approval Date (mm-dd-yyyy)		°N		°W		Range		
								SW NW		Section 1				Township 35 N
Hicap Permanent Well #				Common Well #		Specific Capacity 0.9		2. Well Type New Well						
3. Well serves # of Private, potable				Hicap Well ?		Hicap Property ?		of previous unique well # constructed in						
								Reason for replaced or reconstructed well ?						
Heat Exchange ___ # of drillholes				Hicap Potable ?		Construction Type Drilled								
4. Potential Contamination Sources - ON REVERSE SIDE														
5. Drillhole Dimensions and Construction Method														
Dia. (in.) 6		From (ft.) Surface		To (ft.) 39		Upper Enlarged Drillhole				Lower Open Bedrock				
		Rotary - Mud Circulation												
		Rotary - Air												
		Rotary - Air & Foam												
		Drill-Through Casing Hammer												
		Reverse Rotary												
		Cable-tool Bit ___ in. dia...												
		Dual Rotary												
Temp. Outer Casing ___ in. dia		Removed? ___ depth ft. (If NO explain on back side)												
8. Geology														
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)				
Q		S		CAVING SAND				Surface		31				
S		M		SAND & SILT				31		35				
N		S		FINE SAND				35		39				
6. Casing, Liner, Screen														
Dia. (in.) 6		Material, Weight, Specification Manufacturer & Method of Assembly A53 GRADE B PLAINEND WELDED SAWHILL				From (ft.) Surface		To (ft.) 36		11. Well Is 12 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes				
Dia. (in.) 6		Screen type, material & slot size SATINLESS STEEL 7 SLOT				From (ft.) 36		To (ft.) 39						
7. Grout or Other Sealing Material														
Method														
Kind of Sealing Material				From (ft.) Surface		To (ft.)		# Sacks Cement						
9. Static Water Level														
19 ft. below ground surface														
10. Pump Test														
Pumping level 31 ft. below surface														
Pumping at 11 GP M for 2 Hrs.														
Pumping Method ?														
12. Notified Owner of need to fill & seal ?														
Filled & Sealed Well(s) as needed?														
13. Constructor / Supervisory Driller														
DF								Lic #		Date Signed 01-11-2000				
Drill Rig Operator								Lic or Reg #		Date Signed				

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		16	Septic or Holding, or POWTS Tank		50
			POWTS dispersal component (soil absorption unit or mound)		60

Comment:

Created On: 06-16-2000

Updated On: 06-16-2000

Review Status: