Well Construction Report
WISCONSIN UNIQUE WELL NUMBER NS217

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: DIEMERT, TIM			Phone #
Mailing Address: PO BOX 53 834 CTY J			
City: FRIENDSHIP	State: WI	Zip Code: 53934	
County: Adams	Co. Permit #	Notification #	Completed: 07-25-2000

Well Constructor (Business Name): RAY E FOSTER	Lic #: 164	Facility ID # (Public Wells)	
Address: 2502 STATE RD 13 ADAMS WI 53910-9739		Well Plan Approval #	
		Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #	Specific Capacity	

1. Well Location

Town of PRESTON

Fire # (if avail.): 834

Street Address or Road Name and Number: 834 COUNTY J

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)				Method Code
43.984 °N	-89.7443 °W			GCD013
NE SE or Govt Lot #	Section: 35	Township: 18 N	Range: 6 E	

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Jetted

3. Well serves 1 # of GARDEN WELL BY GARAGE

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	6
2	6	44

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
	N	S		FINE SAND	Surface	10
		C	I	CLAY LOAM	10	20
	M	S		MEDIUM SAND	20	35
	A	Y		COARSE SAND & GRAVEL	35	44

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
2	SAWHILL TYPE II ASTM A-589 3.75 THREADED & COUPLED	Surface	40
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
1.25	CAMPBELL SS 10 SLOT	40	44

9. Static Water Level

22 ft. below ground surface

10. Pump Test

Pumping level 22 ft. below surface

Pumping at 10 GP M for 1 Hrs.

Pumping Method ?

11. Well Is

24 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
MUD & CUTTINGS	Surface	6	

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No

NONE

13. Constructor / Supervisory Driller	Lic #	Date Signed
DSF		07-30-2000
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		69	Building Overhang		2
			Septic or Holding, or POWTS Tank		110

Comment:

Created On: 09-15-2000 Updated On: 05-04-2020 Review Status: