

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				NS217		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A												
Property Owner DIEMERT, TIM						Phone #		1. Well Location				Fire # (if avail.)										
Mailing Address PO BOX 53 834 CTY J								Town of PRESTON				834										
City FRIENDSHIP						State WI		Zip Code 53934		Street Address or Road Name and Number												
County Adams						Co. Permit #		Notification #		Completed 07-25-2000		Subdivision Name		Lot #		Block #						
Well Constructor (Business Name)						Lic. #		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD)				Method Code								
RAY E FOSTER						164				43.984 °N -89.7443 °W				GCD013								
Address 2502 STATE RD 13 ADAMS WI 53910-9739								Well Plan Approval #		NE SE		Section Township		Range								
								Approval Date (mm-dd-yyyy)		or Govt Lot #		35 18 N		6 E								
Hicap Permanent Well #						Common Well #		Specific Capacity		2. Well Type New Well												
3. Well serves 1 # of GARDEN WELL BY GARAGE						Hicap Well ? No		of previous unique well # constructed in														
Private,potable						Hicap Property ? No		Reason for replaced or reconstructed well ?														
Heat Exchange___# of drillholes						Hicap Potable ?		Construction Type Jetted														
4. Potential Contamination Sources - ON REVERSE SIDE																						
5. Drillhole Dimensions and Construction Method										8. Geology												
Dia. (in.)			From (ft.)			To (ft.)			Upper Enlarged Drillhole			Lower Open Bedrock			Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
6			Surface			6			Rotary - Mud Circulation						N S		FINE SAND		Surface		10	
2			6			44			Rotary - Air						C I		CLAY LOAM		10		20	
									Rotary - Air & Foam						M S		MEDIUM SAND		20		35	
									Drill-Through Casing Hammer						A Y		COARSE SAND & GRAVEL		35		44	
									Reverse Rotary													
									Cable-tool Bit ___in. dia...													
									Dual Rotary													
									Temp. Outer Casing ___in. dia													
									Removed? ___depth ft. (If NO explain on back side)													
6. Casing, Liner, Screen										9. Static Water Level				11. Well Is								
Dia. (in.)			Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		22 ft. below ground surface				24 in. above grade							
2			SAWHILL TYPE II ASTM A-589 3.75 THREADED & COUPLED				Surface		40		10. Pump Test				Developed ? Yes							
Dia. (in.)			Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 22 ft. below surface				Disinfected ? Yes							
1.25			CAMPBELL SS 10 SLOT				40		44		Pumping at 10 GP M for 1 Hrs.				Capped ? Yes							
7. Grout or Other Sealing Material										12. Notified Owner of need to fill & seal ?												
Method																						
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed?						No						
MUD & CUTTINGS				Surface		6				NONE												
13. Constructor / Supervisory Driller										Lic #		Date Signed										
DSF												07-30-2000										
Drill Rig Operator										Lic or Reg #		Date Signed										

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		69	Building Overhang		2
			Septic or Holding, or POWTS Tank		110

Comment:

Created On: 09-15-2000

Updated On: 05-04-2020

Review Status: