

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	50	Landfill	>	1200
Building Overhang	>	10	Sewer - Building Sanitary	>	25
Shoreline/Pool	>	25	Septic or Holding, or POWTS Tank	>	25

Comment: NON SENT 020601 RE: < REQUIRED CASING.

Variance ID	Variance or Exception Type	Date	Reason
	Casing Depth Variance	03/12/2001	< REQUIRED CASING - SAMPLING RESULTS REQUIRED BEFORE VARIANCE APPROVAL
	Casing Depth Variance	06/19/2001	< REQUIRED CASING - VARIANCE APPROVED

Created On: 10-09-2001**Updated On:** 06-11-2020**Review Status:**