Well Construction Report
WISCONSIN UNIQUE WELL NUMBER NX560

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: SCHULTZE, BOB			Phone #
Mailing Address: 6232 E ROCKDALE RD			
City: SOUTH RANGE	State: WI	Zip Code: 54874	
County: Douglas	Co. Permit #	Notification #	Completed: 12-10-1999

Well Constructor (Business Name): LIND LARRY WELL DRILLING INC	Lic. #: 432	Facility ID # (Public Wells)	
Address: RR 1 BOX 278 IRON RIVER WI 54847-9636		Well Plan Approval #	
		Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #	Specific Capacity: 1.5	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location

Town of OAKLAND

Fire # (if avail.): 6232

Street Address or Road Name and Number: E ROCKDALE RD

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)	Method Code
46.5387 °N -91.982 °W	GCD013

NE SW or Govt Lot #	Section	Township	Range
	22	47 N	13 W

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	79
6	79	270

Upper Enlarged Drillhole — Lower Open Bedrock

Yes Rotary - Mud Circulation .....
Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
P	HARDPAN	Surface	79
B	BASALT ROCK	79	270

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	PLAIN END IPSCO ASTM A53B .280 18.97	Surface	79
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method PUMPING

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
BENTONITE & CUTTINGS	Surface	79	

9. Static Water Level
8 ft. below ground surface

10. Pump Test
Pumping level 28 ft. below surface
Pumping at 30 GP M for 8 Hrs.
Pumping Method ?

11. Well Is
14 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?
NA

13. Constructor / Supervisory Driller	Lic #	Date Signed
LL		01-03-2000
Drill Rig Operator	Lic or Reg #	Date Signed
KL		01-03-2000

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		100	Septic or Holding, or POWTS Tank		52

Comment:

Created On: 02-03-2000 Updated On: 06-25-2020 Review Status: