Well Construction Report
WISCONSIN UNIQUE WELL NUMBER NX561

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: SUPERIOR, CITY OF PLANING & DE			Phone #
Mailing Address: 1409 HAMMOND AVE			
City: SUPERIOR	State: WI	Zip Code: 54880	
County: Douglas	Co. Permit #:	Notification #:	Completed: 12-16-1999

Well Constructor (Business Name): LIND LARRY WELL DRILLING INC	Lic. #: 432	Facility ID # (Public Wells):	
Address: RR 1 BOX 278 IRON RIVER WI 54847-9636		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0.2	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location

Town of PARKLAND				Fire # (if avail.): 3495
Street Address or Road Name and Number: S CTY RD E				
Subdivision Name: E SUP 3RD DIV			Lot #:	Block #:
Latitude / Longitude in Decimal Degree (DD): 46.6349 °N -91.9851 °W				Method Code: GCD013
SE SW or Govt Lot #	Section: 15	Township: 48 N	Range: 13 W	

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
OLD WELL USAGE

Construction Type Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	303
6	303	329

Upper Enlarged Drillhole — Lower Open Bedrock

Yes Rotary - Mud Circulation .....
Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		C	P	CLAY HARDPAN	Surface	303
		N		SANDSTONE	303	329

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	PLAINEND IPSCO ASTM A53B .280 18.97	Surface	303
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method PUMPING

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
BENTONITE & CUTTINGS	Surface	303	

9. Static Water Level
75 ft. below ground surface

10. Pump Test
Pumping level 150 ft. below surface
Pumping at 12 GP M for 48 Hrs.
Pumping Method ?

11. Well Is
16 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
LL		01-03-2000
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
KL		01-03-2000

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Septic or Holding, or POWTS Tank		40

Comment:

Created On: 02-03-2000 Updated On: 06-25-2020 Review Status: