

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				NX562		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner MANNETTER, DREW						Phone #		1. Well Location				Fire # (if avail.)	
Mailing Address 10792 E BARDON CREEK						Town of LAKESIDE						10792	
City POPLAR						State WI		Zip Code 54864				Street Address or Road Name and Number	
E BARDON CREEK RD						Subdivision Name				Lot #		Block #	
County Douglas		Co. Permit #		Notification #		Completed 12-20-1999		Latitude / Longitude in Decimal Degree (DD)				Method Code	
Well Constructor (Business Name) LIND LARRY WELL DRILLING INC				Lic. # 432		Facility ID # (Public Wells)				46.6243 °N -91.7446 °W		GCD013	
Address RR 1 BOX 278 IRON RIVER WI 54847-9636				Well Plan Approval #		NW SW		Section 21		Township 48 N		Range 11 W	
				Approval Date (mm-dd-yyyy)		or Govt Lot #							
Hicap Permanent Well #		Common Well #		Specific Capacity 0.4		2. Well Type New Well				of previous unique well # constructed in			
Reason for replaced or reconstructed well ?						UP DATING OLD WELL							
3. Well serves 1 # of Private, potable						Hicap Well ? No		Construction Type Drilled					
Heat Exchange ___ # of drillholes						Hicap Property ?		Hicap Potable ?					
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock										
8.75 Surface 92			Yes Rotary - Mud Circulation										
6 92 210			Rotary - Air										
			Rotary - Air & Foam										
			Drill-Through Casing Hammer										
			Reverse Rotary										
			Cable-tool Bit ___ in. dia...										
			Dual Rotary										
			Temp. Outer Casing ___ in. dia										
			Removed? ___ depth ft. (If NO explain on back side)										
8. Geology													
Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...						From (ft.)		To (ft.)		
C			CLAY						Surface		92		
N			SANDSTONE						92		210		
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level			
6		PLAINE END IPSCO ASTM A53 B .280 18.97				Surface		92		80 ft. below ground surface			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		10. Pump Test			
										Pumping level 107 ft. below surface			
										Pumping at 12 GP M for 2 Hrs.			
										Pumping Method ?			
7. Grout or Other Sealing Material													
Method PUMPING													
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement							
BENTONITE & CUTTINGS		Surface		92									
11. Well Is													
16 in. above grade													
Developed ? Yes													
Disinfected ? Yes													
Capped ? Yes													
12. Notified Owner of need to fill & seal ?													
Filled & Sealed Well(s) as needed? Yes													
13. Constructor / Supervisory Driller						Lic #		Date Signed					
LL								01-03-2000					
Drill Rig Operator						Lic or Reg #		Date Signed					
KL								01-03-2000					

4a. Potential Contamination Sources

Is the well located in floodplain ?

Type	Qualifier	Distance
Septic or Holding, or POWTS Tank		50

Comment:

Created On: 02-03-2000

Updated On: 06-25-2020

Review Status: