Well Construction Report
WISCONSIN UNIQUE WELL NUMBER NX562

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: MANNETTER, DREW	Phone #
Mailing Address: 10792 E BARDON CREEK	
City: POPLAR	State: WI — Zip Code: 54864
County: Douglas	Co. Permit #	Notification #	Completed: 12-20-1999
Well Constructor (Business Name): LIND LARRY WELL DRILLING INC	Lic. #: 432	Facility ID # (Public Wells)
Address: RR 1 BOX 278 IRON RIVER WI 54847-9636	Well Plan Approval #	Approval Date (mm-dd-yyyy)
Hicap Permanent Well #	Common Well #	Specific Capacity: 0.4

1. Well Location

Town of LAKESIDE	Fire # (if avail.): 10792
Street Address or Road Name and Number: E BARDON CREEK RD	
Subdivision Name	Lot #	Block #
Latitude / Longitude in Decimal Degree (DD): 46.6243 °N -91.7446 °W	Method Code: GCD013

NW	SW	Section	Township	Range
or Govt Lot #		21	48 N	11 W

2. Well Type New Well
of previous unique well # constructed in
Reason for replaced or reconstructed well ?: UP DATING OLD WELL
Construction Type: Drilled

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes
Hicap Well ? No
Hicap Property ?
Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	92
6	92	210

Upper Enlarged Drillhole — Lower Open Bedrock

Yes Rotary - Mud Circulation .....
Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
C	CLAY	Surface	92
N	SANDSTONE	92	210

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	PLAINE END IPSCO ASTM A53 B .280 18.97	Surface	92
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level
80 ft. below ground surface

10. Pump Test
Pumping level 107 ft. below surface
Pumping at 12 GP M for 2 Hrs.
Pumping Method ?

11. Well Is
16 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method PUMPING

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
BENTONITE & CUTTINGS	Surface	92	

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
LL		01-03-2000
Drill Rig Operator	Lic or Reg #	Date Signed
KL		01-03-2000

4a. Potential Contamination Sources Is the well located in floodplain ?

Type	Qualifier	Distance
Septic or Holding, or POWTS Tank		50

Comment:

Created On: 02-03-2000 Updated On: 06-25-2020 Review Status: