Well Construction Report
WISCONSIN UNIQUE WELL NUMBER: NX565

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: MILLER, GENE	Phone #
Mailing Address: PO BOX 125	
City: HAWTHORNE	State: WI — Zip Code: 54842
County: Douglas	Co. Permit #: — Notification #: — Completed: 12-29-1999
Well Constructor (Business Name): LIND LARRY WELL DRILLING INC	Lic. #: 432 — Facility ID # (Public Wells):
Address: RR 1 BOX 278, IRON RIVER WI 54847-9636	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 0

1. Well Location

Town of HAWTHORNE	Fire # (if avail.): 7513S
Street Address or Road Name and Number: IBSON RD	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 46.4937 °N -91.8215 °W	Method Code: GCD013
SE SE or Govt Lot #:	Section: 2 — Township: 46 N — Range: 12 W

2. Well Type New Well
of previous unique well #: — constructed in:
Reason for replaced or reconstructed well ?:
Construction Type: Drilled

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes
Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	97
6	97	230

Upper Enlarged Drillhole — Lower Open Bedrock

Yes Rotary - Mud Circulation .....
Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
P	HARDPAN	Surface	97
B	BASALT ROCK	97	230

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	PLAINEND IPSCO ASTM A53B .280 18.97	Surface	97
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level
25 ft. below ground surface

10. Pump Test
Pumping level 200 ft. below surface
Pumping at 3 GP M for 2 Hrs.
Pumping Method ?

11. Well Is
15 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method PUMPING

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
BENTONITE & CUTTINGS	Surface	97	

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed?
NA

13. Constructor / Supervisory Driller	Lic #	Date Signed
LL		01-04-2000
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
KL		01-04-2000

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		80	Septic or Holding, or POWTS Tank		70

Comment:

Created On: 02-03-2000 Updated On: 10-15-2026 Review Status: