

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				NX565		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A	
Property Owner MILLER, GENE					Phone #		1. Well Location Fire # (if avail.) 7513S				
Mailing Address PO BOX 125											
City HAWTHORNE				State WI		Zip Code 54842		Town of HAWTHORNE Street Address or Road Name and Number IBSON RD			
County Douglas		Co. Permit #		Notification #		Completed 12-29-1999		Subdivision Name		Lot # Block #	
Well Constructor (Business Name) LIND LARRY WELL DRILLING INC				Lic. # 432		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 46.4937 °N -91.8215 °W		Method Code GCD013	
Address RR 1 BOX 278 IRON RIVER WI 54847-9636				Well Plan Approval #		SE SE Section Township Range or Govt Lot # 2 46 N 12 W		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled			
				Approval Date (mm-dd-yyyy)							
Hicap Permanent Well #		Common Well #		Specific Capacity							
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?							
4. Potential Contamination Sources - ON REVERSE SIDE											
5. Drillhole Dimensions and Construction Method											
Dia. (in.) From (ft.) To (ft.) 8.75 Surface 97 6 97 230			Upper Enlarged Drillhole Lower Open Bedrock Yes Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)								
8. Geology											
			Geology Codes P HARDPAN B BASALT ROCK			Type, Caving/Noncaving, Color, Hardness, etc... From (ft.) To (ft.) Surface 97 97 230					
6. Casing, Liner, Screen											
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.) To (ft.)					
6		PLAINEND IPSCO ASTM A53B .280 18.97				Surface 97					
Dia. (in.)		Screen type, material & slot size				From (ft.) To (ft.)					
7. Grout or Other Sealing Material											
Method PUMPING											
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement					
BENTONITE & CUTTINGS		Surface		97							
9. Static Water Level 25 ft. below ground surface											
10. Pump Test Pumping level 200 ft. below surface Pumping at 3 GP M for 2 Hrs. Pumping Method ?											
11. Well Is 15 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes											
12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? NA											
13. Constructor / Supervisory Driller								Lic #		Date Signed	
LL										01-04-2000	
Drill Rig Operator								Lic or Reg #		Date Signed	
KL										01-04-2000	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		80	Septic or Holding, or POWTS Tank		70

Comment:

Created On: 02-03-2000

Updated On: 06-25-2020

Review Status: