Well Construction Report
WISCONSIN UNIQUE WELL NUMBER NY064

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: THOMAS, EUGENE	Phone #
Mailing Address: 27530 CTY P	
City: KENDALL	State: WI / Zip Code: 54638
County: Monroe	Co. Permit # / Notification # / Completed: 08-04-2000
Well Constructor (Business Name): KARL M WALKER	Lic. #: 103 / Facility ID # (Public Wells)
Address: 3199 8TH AVE, WISCONSIN DELLS WI 53965-8998	Well Plan Approval # / Approval Date (mm-dd-yyyy)
Hicap Permanent Well #	Common Well # / Specific Capacity: 1.1

1. Well Location

Town of WELLINGTON	Fire # (if avail.): 27530
Street Address or Road Name and Number: CTY P	
Subdivision Name	Lot # / Block #
Latitude / Longitude in Decimal Degree (DD): 43.7736 °N -90.4421 °W	Method Code: GCD013
NW SE or Govt Lot #	Section: 13 / Township: 15 N / Range: 1 W

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	140
6	140	180

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes — Rotary - Air ..... — No
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	Z	L	CLAY & LIMESTONE GRAVEL	Surface	21
-	-	L	-	LIMESTONE	21	152
-	-	N	-	SANDSTONE	152	180

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	PE WELDED STEEL SAWHILL A-53 .280 WALL	Surface	140
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

142 ft. below ground surface

10. Pump Test

Pumping level 160 ft. below surface

Pumping at 20 GP M for 4 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method TREMMIE PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
PORTLAND	Surface	140	14 S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
KMW		01-17-2001
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
KMW		

4a. Potential Contamination Sources Is the well located in floodplain ?

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		180

Type	Qualifier	Distance
Building Overhang		8
Septic or Holding, or POWTS Tank		27

Comment:

Created On: 08-29-2001 Updated On: 04-29-2020 Review Status: