

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				NY072		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner TOLLESON, ROBERTA						Phone # (608)742-2724		1. Well Location				Fire # (if avail.)			
Mailing Address 932 FAIRFIELD ST						Town of PACIFIC						932			
City PORTAGE						State WI		Zip Code 53901				Street Address or Road Name and Number FAIRFIELD ST			
County Columbia		Co. Permit #		Notification #		Completed 08-03-2000		Subdivision Name				Lot # Block #			
Well Constructor (Business Name) KARL M WALKER				Lic. # 103		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.53243 °N -89.47895 °W				Method Code GPS008	
Address 3199 8TH AVE WISCONSIN DELLS WI 53965-8998				Well Plan Approval #		SW NW Section Township Range or Govt Lot # 7 12 N 9 E		2. Well Type Replacement of previous unique well # constructed in Reason for replaced or reconstructed well ? NON-CODE DRIVEN POINT Construction Type Drilled							
Approval Date (mm-dd-yyyy)				Approval Date (mm-dd-yyyy)		SW NW Section Township Range or Govt Lot # 7 12 N 9 E									
Hicap Permanent Well #		Common Well #		Specific Capacity 0.7											
3. Well serves 1 # of HOME Private, potable Heat Exchange ___ # of drillholes						Hicap Well ? No Hicap Property ? No Hicap Potable ?									
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole Lower Open Bedrock									
9		Surface		94		Yes Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)									
4		94		99											
8. Geology															
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)							
C		CLAY				Surface		6							
Y		SAND & GRAVEL				6		40							
C		CLAY				40		54							
N S C		FINE SAND W/CLAY				54		85							
A S		COARSE SAND				85		99							
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)							
5		HASTING EAGLE SDR21 D2241 ASTM F480-90 200 PSI				Surface		95							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
4		STAIN WIRE WRAP 12				95		99							
7. Grout or Other Sealing Material															
Method TREMMIE PUMPED															
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement									
BENTONITE SLURRY W/CUTTINGS		Surface		95		11 S									
9. Static Water Level															
5 ft. below ground surface															
10. Pump Test															
Pumping level 60 ft. below surface Pumping at 40 GP M for 3 Hrs. Pumping Method ?															
11. Well Is															
12 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes															
12. Notified Owner of need to fill & seal ?															
Filled & Sealed Well(s) as needed? Yes															
13. Constructor / Supervisory Driller						Lic #		Date Signed							
KMW								08-07-2000							
Drill Rig Operator						Lic or Reg #		Date Signed							
CC								08-07-2000							

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment:

Created On: 09-13-2000

Updated On: 08-23-2022

Review Status: