Well Construction Report
WISCONSIN UNIQUE WELL NUMBER NY072

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: TOLLESON, ROBERTA	Phone #: (608)742-2724
Mailing Address: 932 FAIRFIELD ST	
City: PORTAGE	State: WI — Zip Code: 53901
County: Columbia	Co. Permit #: — Notification #: — Completed: 08-03-2000
Well Constructor (Business Name): KARL M WALKER	Lic. #: 103 — Facility ID # (Public Wells):
Address: 3199 8TH AVE, WISCONSIN DELLS WI 53965-8998	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 0.7

1. Well Location

Town of PACIFIC	Fire # (if avail.): 932
Street Address or Road Name and Number: FAIRFIELD ST	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 43.53243 °N -89.47895 °W	Method Code: GPS008
SW NW or Govt Lot #:	Section: 7 — Township: 12 N — Range: 9 E

2. Well Type Replacement

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?: NON-CODE DRIVEN POINT

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
9	Surface	94
4	94	99

Upper Enlarged Drillhole — Lower Open Bedrock

Yes — Rotary - Mud Circulation .....
Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		C		CLAY	Surface	6
		Y		SAND & GRAVEL	6	40
		C		CLAY	40	54
	N	S	C	FINE SAND W/CLAY	54	85
	A	S		COARSE SAND	85	99

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
5	HASTING EAGLE SDR21 D2241 ASTM F480-90 200 PSI	Surface	95
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
4	STAIN WIRE WRAP 12	95	99

9. Static Water Level

5 ft. below ground surface

10. Pump Test

Pumping level 60 ft. below surface

Pumping at 40 GP M for 3 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method TREMMIE PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
BENTONITE SLURRY W/CUTTINGS	Surface	95	11 S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
KMW		08-07-2000
Drill Rig Operator	Lic or Reg #	Date Signed
CC		08-07-2000

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Created On: 09-13-2000 Updated On: 08-23-2022 Review Status: