

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				NZ012		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707 Form 3300-077A						
Property Owner WEDDEL, LARRY					Phone #							
Mailing Address N2427 CRISPUS ATTUCK					1. Well Location					Fire # (if avail.)		
City BURLINGTON					State WI	Zip Code 53105						
County Walworth	Co. Permit #	Notification #			Completed 05-02-2000		Town of BLOOFIELD			Street Address or Road Name and Number		
						N2427 CRISPUS ATTUCKS			Subdivision Name			
									Lot #	Block #		
Well Constructor (Business Name)				Lic. #	Facility ID # (Public Wells)			Latitude / Longitude in Decimal Degree (DD)			Method Code	
RICHARD L DANECKI				124				42.5786 °N -88.3454 °W			GCD013	
Address PO BOX 94 NORTH PRAIRIE WI 53153-0094				Well Plan Approval #			NW	NW	Section	Township	Range	
				Approval Date (mm-dd-yyyy)			or Govt Lot #	3	1	N	18 E	
Hicap Permanent Well #		Common Well #		Specific Capacity			2. Well Type New Well					
				0.5			of previous unique well # constructed in					
3. Well serves 1 # of				Hicap Well ? No			Reason for replaced or reconstructed well ?					
Private, potable				Hicap Property ? No								
Heat Exchange ___ # of drillholes				Hicap Potable ?			Construction Type Drilled					
4. Potential Contamination Sources - ON REVERSE SIDE												
5. Drillhole Dimensions and Construction Method												
Dia. (in.)	From (ft.)	To (ft.)	Upper Enlarged Drillhole				Lower Open Bedrock					
6	Surface	145										
			Rotary - Mud Circulation									
			Rotary - Air									
			Rotary - Air & Foam									
			Drill-Through Casing Hammer									
			Reverse Rotary									
			Cable-tool Bit ___ in. dia...									
			Dual Rotary									
			Temp. Outer Casing ___ in. dia									
			Removed? ___ depth ft. (If NO explain on back side)									
8. Geology												
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)				
	Y		SAND & GRAVEL				Surface		38			
	S		SAND				38		74			
G	C	S	GRAY SANDY CLAY				74		111			
	L		LIMESTONE				111		145			
6. Casing, Liner, Screen												
Dia. (in.)	Material, Weight, Specification				From (ft.)	To (ft.)						
	Manufacturer & Method of Assembly											
6	SAW HILL USA STD ERW A53-90 GR BBLACK PLAIN END 6.625 OD X .280 WALL				Surface	111						
Dia. (in.)	Screen type, material & slot size				From (ft.)	To (ft.)						
7. Grout or Other Sealing Material												
Method												
Kind of Sealing Material			From (ft.)	To (ft.)	# Sacks Cement							
#8 MESH BENTONITE			Surface									
9. Static Water Level												
38 ft. below ground surface												
10. Pump Test												
Pumping level 100 ft. below surface												
Pumping at 30 GP M for 3 Hrs.												
Pumping Method ?												
11. Well Is												
12 in. above grade												
Developed ? Yes												
Disinfected ? Yes												
Capped ? Yes												
12. Notified Owner of need to fill & seal ?												
Filled & Sealed Well(s) as needed? No												
NONE												
13. Constructor / Supervisory Driller												
Lic #												
Date Signed												
RLD												
05-02-2000												
Drill Rig Operator												
Lic or Reg #												
Date Signed												

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		75	Downspout/Yard Hydrant		30
Building Overhang		10	Foundation Drain to Clearwater		12
Clearwater Sump		14	Sewer - Building Sanitary		45
			Septic or Holding, or POWTS Tank		60

Comment:

Created On: 07-13-2000

Updated On: 09-12-2019

Review Status: