Well Construction Report
WISCONSIN UNIQUE WELL NUMBER NZ013

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: LEECH, BILL	Phone #
Mailing Address: W345 S10423 WAMBOLD	
City: EAGLE	State: WI — Zip Code: 53119
County: Waukesha	Co. Permit #: — Notification #: — Completed: 05-08-2000
Well Constructor (Business Name): RICHARD L DANECKI	Lic. #: 124 — Facility ID # (Public Wells):
Address: PO BOX 94, NORTH PRAIRIE WI 53153-0094	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 0.7

1. Well Location
Town of EAGLE
Fire # (if avail.):
Street Address or Road Name and Number: W345 S10423 WAMBOLD RD
Subdivision Name: — Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): °N °W — Method Code:
SE NW or Govt Lot #: — Section: 36 — Township: 5 N — Range: 17 E

2. Well Type Replacement
of previous unique well #: — constructed in:
Reason for replaced or reconstructed well ?: BAD POINT
Construction Type: Driven Point

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes
Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	20
6	20	75

Upper Enlarged Drillhole — Lower Open Bedrock
Rotary - Mud Circulation .....
Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Yes Cable-tool Bit 10in. dia...
Dual Rotary .....
Yes Temp. Outer Casing 10in. dia
Yes Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
S	SAND	Surface	18
C	CLAY	18	36
C S	SANDY CLAY	36	45
S	SAND	45	60
Y	SAND & GRAVEL	60	75

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	SAWHILL USA STD ERW A53-90 GR BBLACK PLAIN END 6.625 OD X .280 WALL	Surface	71
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5	SS SCREEN 25 SLOT	71	75

7. Grout or Other Sealing Material
Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
8# CHIPPED BENTONITE	Surface	75	

9. Static Water Level
3 ft. below ground surface

10. Pump Test
Pumping level 20 ft. below surface
Pumping at 12 GP M for 6 Hrs.
Pumping Method ?

11. Well Is
32 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
RLD		05-08-2000
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		8	Shoreline/Pool		50
Downspout/Yard Hydrant		10	Sewer - Building Sanitary		29
			Septic or Holding, or POWTS Tank		35

Comment:

Created On: 10-02-2000 Updated On: 10-02-2000 Review Status: