

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				NZ014		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A													
Property Owner HAASE, CRAIG						Phone #		1. Well Location				Fire # (if avail.)											
Mailing Address W297 N8750 CAMP WHIT								Town of MERTON															
City HARTLAND						State WI		Zip Code 53029															
County Waukesha		Co. Permit #		Notification #		Completed 05-10-2000		Subdivision Name				Lot # 1											
								Block #															
Well Constructor (Business Name) RICHARD L DANECKI				Lic. # 124		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.177 °N -88.3346 °W													
						Well Plan Approval #				Method Code GCD013													
Address PO BOX 94 NORTH PRAIRIE WI 53153-0094						Approval Date (mm-dd-yyyy)				NE NW Section Township Range or Govt Lot # 11 8 N 18 E													
Hicap Permanent Well #				Common Well #		Specific Capacity 0.1				2. Well Type New Well													
3. Well serves 1 # of				Hicap Well ? No						of previous unique well # constructed in													
Private, potable				Hicap Property ? No						Reason for replaced or reconstructed well ?													
Heat Exchange ___ # of drillholes				Hicap Potable ?						Construction Type Drilled													
4. Potential Contamination Sources - ON REVERSE SIDE																							
5. Drillhole Dimensions and Construction Method														8. Geology									
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock				Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
6		Surface		265										Y		SAND & GRAVEL		Surface		28			
						Rotary - Mud Circulation								Z		CLAY & GRAVEL		28		70			
						Rotary - Air								L		LIMESTONE		70		251			
						Rotary - Air & Foam								H		SHALE		251		265			
						Drill-Through Casing Hammer																	
						Reverse Rotary																	
						Cable-tool Bit ___ in. dia...																	
						Dual Rotary																	
						Temp. Outer Casing ___ in. dia																	
						Removed? ___ depth ft. (If NO explain on back side)																	
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is					
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		80 ft. below ground surface				12 in. above grade									
6		SAWHILL USA STD ERW A53-90 GR BBLACK PLAIN END 6.625 OD X .280 WALL				Surface		70		10. Pump Test				Developed ? Yes									
										Pumping level 200 ft. below surface				Disinfected ? Yes									
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping at 15 GP M for 3 Hrs.				Capped ? Yes									
										Pumping Method ?													
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ?									
Method																							
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed? No													
8# MESH BENTONITE				Surface		70				NONE													
13. Constructor / Supervisory Driller								Lic #		Date Signed													
RLD										05-10-2000													
Drill Rig Operator								Lic or Reg #		Date Signed													

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		150	Foundation Drain to Clearwater		14
Building Overhang		12	Sewer - Building Sanitary		60
Clearwater Sump		12	Septic or Holding, or POWTS Tank		75

Comment:

Created On: 07-27-2000

Updated On: 07-11-2019

Review Status: