Well Construction Report
WISCONSIN UNIQUE WELL NUMBER NZ014

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: HAASE, CRAIG	Phone #
Mailing Address: W297 N8750 CAMP WHIT	
City: HARTLAND	State: WI — Zip Code: 53029
County: Waukesha	Co. Permit #	Notification #	Completed: 05-10-2000
Well Constructor (Business Name): RICHARD L DANECKI	Lic. #: 124	Facility ID # (Public Wells)
Address: PO BOX 94 NORTH PRAIRIE WI 53153-0094	Well Plan Approval #	Approval Date (mm-dd-yyyy)
Hicap Permanent Well #	Common Well #	Specific Capacity: 0.1

1. Well Location

Town of MERTON			Fire # (if avail.)
Street Address or Road Name and Number: W297 N8750 CAMP WHITCOMB RD			
Subdivision Name		Lot #: 1	Block #
Latitude / Longitude in Decimal Degree (DD): 43.177 °N -88.3346 °W			Method Code: GCD013
NE NW or Govt Lot #	Section: 11	Township: 8 N	Range: 18 E

2. Well Type New Well
of previous unique well # constructed in
Reason for replaced or reconstructed well ?
Construction Type: Drilled

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes
Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	265

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
Y	SAND & GRAVEL	Surface	28
Z	CLAY & GRAVEL	28	70
L	LIMESTONE	70	251
H	SHALE	251	265

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	SAWHILL USA STD ERW A53-90 GR BBLACK PLAIN END 6.625 OD X .280 WALL	Surface	70
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
8# MESH BENTONITE	Surface	70	

9. Static Water Level
80 ft. below ground surface

10. Pump Test
Pumping level 200 ft. below surface
Pumping at 15 GP M for 3 Hrs.
Pumping Method ?

11. Well Is
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed? No
NONE

13. Constructor / Supervisory Driller	Lic #	Date Signed
RLD		05-10-2000
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		150	Foundation Drain to Clearwater		14
Building Overhang		12	Sewer - Building Sanitary		60
Clearwater Sump		12	Septic or Holding, or POWTS Tank		75

Comment:

Created On: 07-27-2000 Updated On: 07-11-2019 Review Status: