Well Construction Report
WISCONSIN UNIQUE WELL NUMBER NZ654

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: WARWICK, RICHARD	Phone #: (715)258-0870
Mailing Address: E2311 NANCY LN	
City: WAUPACA	State: WI — Zip Code: 54981
County: Waupaca	Co. Permit #: — Notification #: — Completed: 10-20-2002
Well Constructor (Business Name): STANLEY JOHNSON	Lic. #: 189 — Facility ID # (Public Wells):
Address: E 1480 RURAL RD WAUPACA WI 54981	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 1.1

1. Well Location

Town of FARMINGTON	Fire # (if avail.): E2311
Street Address or Road Name and Number: NANCY LN	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 44.3447 °N -89.1116 °W	Method Code: GCD013
SW SE or Govt Lot #:	Section: 25 — Township: 22 N — Range: 11 E

2. Well Type Replacement

of previous unique well # — constructed in

Reason for replaced or reconstructed well ?
OLD WELL DIDN'T PRODUCE E

Construction Type: Drilled

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	15
4	15	152

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....

Yes Temp. Outer Casing 8in. dia

Yes Removed? 15depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	S	-	SAND	Surface	50
G	N	S	U	GRAY FIND STICKY SAND	50	100
T	N	S	U	BROWN FINE STICKY SAND	100	145
-	-	S	-	CLEAN SAND	145	152

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	ASTM A53B T&C IPS CO	Surface	148
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
2	STAINLESS STEEL 7 SLOT	148	152

9. Static Water Level
30 ft. below ground surface

10. Pump Test
Pumping level 39 ft. below surface
Pumping at 10 GP M for 1 Hrs.
Pumping Method ?

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
BENTONITE	Surface		

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
Drill Rig Operator	Lic or Reg #	Date Signed
ST		11-04-2002

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		55

Type	Qualifier	Distance
Building Overhang		2
Septic or Holding, or POWTS Tank		50

Comment:

Created On: 01-10-2003 Updated On: 05-08-2020 Review Status: