

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				NZ654		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner WARWICK, RICHARD						Phone # (715)258-0870		1. Well Location				Fire # (if avail.)			
Mailing Address E2311 NANCY LN						Town of FARMINGTON						E2311			
City WAUPACA						State WI		Zip Code 54981				Street Address or Road Name and Number NANCY LN			
County Waupaca		Co. Permit #		Notification #		Completed 10-20-2002		Subdivision Name				Lot # Block #			
Well Constructor (Business Name) STANLEY JOHNSON				Lic. # 189		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.3447 °N -89.1116 °W				Method Code GCD013	
Address E 1480 RURAL RD WAUPACA WI 54981				Well Plan Approval # Approval Date (mm-dd-yyyy)		SW SE		Section 25		Township 22 N		Range 11 E			
						or Govt Lot #									
Hicap Permanent Well #				Common Well #		Specific Capacity 1.1				2. Well Type Replacement of previous unique well # constructed in Reason for replaced or reconstructed well ? OLD WELL DIDN'T PRODUCE E					
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?		Construction Type Drilled									
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole Lower Open Bedrock				Geology Codes Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.) To (ft.)			
8		Surface		15		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary <u>Yes</u> Temp. Outer Casing 8in. dia <u>Yes</u> Removed? 15depth ft. (If NO explain on back side)				- - S -		SAND		Surface 50	
4		15		152						G N S U		GRAY FIND STICKY SAND		50 100	
										T N S U		BROWN FINE STICKY SAND		100 145	
										- - S -		CLEAN SAND		145 152	
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level 30 ft. below ground surface					
4		ASTM A53B T&C IPS CO				Surface		148		10. Pump Test Pumping level 39 ft. below surface Pumping at 10 GP M for 1 Hrs. Pumping Method ?					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		11. Well Is 18 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes					
2		STAINLESS STEEL 7 SLOT				148		152							
7. Grout or Other Sealing Material															
Method Kind of Sealing Material From (ft.) To (ft.) # Sacks Cement BENTONITE Surface															
12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? Yes															
13. Constructor / Supervisory Driller								Lic #		Date Signed					
Drill Rig Operator								Lic or Reg #		Date Signed					
ST										11-04-2002					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		2	Septic or Holding, or POWTS Tank		50
			POWTS dispersal component (soil absorption unit or mound)		55

Comment:

Created On: 01-10-2003

Updated On: 05-08-2020

Review Status: