Well Construction Report
WISCONSIN UNIQUE WELL NUMBER OB770

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: ACCENT HOMES			Phone #
Mailing Address: N56 W33138 IVY LN			
City: NASHOTAH	State: WI	Zip Code: 53058	
County: Waukesha	Co. Permit #	Notification #	Completed: 12-10-2001

Well Constructor (Business Name): D & D DRILLING CO INC	Lic #: 119	Facility ID # (Public Wells)	
Address: 36110 THOMAS DR OCONOMOWOC WI 53066		Well Plan Approval #	
		Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #	Specific Capacity: 0.8	

1. Well Location

Town of OCONOMOWOC

Fire # (if avail.)

Street Address or Road Name and Number: N66 W38350 DEER CREEK CT

Subdivision Name: WOOD LK	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD): 43.1411 °N -88.5063 °W

Method Code: GCD013

NW SE or Govt Lot #	Section	Township	Range
	20	8 N	17 E

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	46

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
Y	-	Y	-	SAND & GRAVEL-YELLOW	Surface	26
G	-	C	-	CLAY-GRAY	26	31
-	-	Y	-	SAND & GRAVEL	31	46

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW, BLK, P.E. 18.97 ASTM A-53 SAWHILL	Surface	43
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	S.S. SCREEN #18 SLOT	43	46

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
	Surface		

9. Static Water Level

8 ft. below ground surface

10. Pump Test

Pumping level 32 ft. below surface

Pumping at 20 GP M for 4 Hrs.

Pumping Method ?

11. Well Is

14 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
CJ		12-19-2001
Drill Rig Operator	Lic or Reg #	Date Signed
DJ		12-19-2001

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		60
Building Overhang		14
Clearwater Sump		15
Downspout/Yard Hydrant		12

Type	Qualifier	Distance
Foundation Drain to Clearwater		16
Wastewater Sump		45
Sewer - Building Sanitary		55
Septic or Holding, or POWTS Tank		70

Comment:

Created On: 01-28-2002 Updated On: 07-12-2019 Review Status: