Well Construction Report
WISCONSIN UNIQUE WELL NUMBER OB775

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: BUSS, MICHEAL			Phone #
Mailing Address: N7821 DIVISION ST			
City: OCONOMOWOC	State: WI	Zip Code: 53066	
County: Jefferson	Co. Permit #	Notification #	Completed: 01-24-2002

Well Constructor (Business Name): D & D DRILLING CO INC	Lic. # 119	Facility ID # (Public Wells)	
Address: 36110 THOMAS DR OCONOMOWOC WI 53066		Well Plan Approval #	
		Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #	Specific Capacity: 5	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of IXONIA

Fire # (if avail.)

Street Address or Road Name and Number: N8994 HUSTIFORD RD

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)				Method Code
43.169 °N	-88.6465 °W			GCD013

SW	SE	Section	Township	Range
or Govt Lot #		7	8 N	16 E

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	100

Upper Enlarged Drillhole / Lower Open Bedrock

Rotary - Mud Circulation .....
Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
G	-	G	G	GRAVEL, ROCKS-GRAY	Surface	26
G	-	Y	-	SAND & GRAVEL-GRAY	26	35
G	-	C	G	GRAVELLY CLAY-GRAY	35	49
-	-	L	-	LIMESTONE	49	100

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW, BLK, 18.97 P.E. ASTM A53B MFG IPSCO	Surface	50
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material
Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
	Surface		

9. Static Water Level
48 ft. below ground surface

10. Pump Test
Pumping level 52 ft. below surface
Pumping at 20 GP M for 2 Hrs.
Pumping Method ?

11. Well Is
16 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
CJ		01-25-2002
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
DP		

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		55
Building Overhang		10
Clearwater Sump		14

Type	Qualifier	Distance
Downspout/Yard Hydrant		10
Foundation Drain to Clearwater		9
Sewer - Building Sanitary		14
Septic or Holding, or POWTS Tank		50

Comment:

Created On: 02-06-2002 Updated On: 09-26-2019 Review Status: