

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				OB775		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner BUSS, MICHEAL						Phone #		1. Well Location				Fire # (if avail.)			
Mailing Address N7821 DIVISION ST						Town of IXONIA						Street Address or Road Name and Number N8994 HUSTIFORD RD			
City OCONOMOWOC				State WI		Zip Code 53066									
County Jefferson		Co. Permit #		Notification #		Completed 01-24-2002		Subdivision Name				Lot #		Block #	
Well Constructor (Business Name) D & D DRILLING CO INC				Lic. # 119		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.169 °N -88.6465 °W				Method Code GCD013	
Address 36110 THOMAS DR OCONOMOWOC WI 53066				Well Plan Approval #				SW SE		Section 7		Township 8 N		Range 16 E	
				Approval Date (mm-dd-yyyy)				or Govt Lot #		7		8 N		16 E	
Hicap Permanent Well #			Common Well #			Specific Capacity 5				2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled					
3. Well serves 1 # of Private, potable						Hicap Well ? No									
Heat Exchange ___ # of drillholes						Hicap Property ? No									
Heat Exchange ___ # of drillholes						Hicap Potable ?									
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock					
6		Surface		100		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)									
8. Geology															
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)					
G		-		G		G		GRAVEL, ROCKS-GRAY		Surface		26			
G		-		Y		-		SAND & GRAVEL-GRAY		26		35			
G		-		C		G		GRAVELLY CLAY-GRAY		35		49			
-		-		L		-		LIMESTONE		49		100			
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)							
6		NEW, BLK, 18.97 P.E. ASTM A53B MFG IPSCO				Surface		50							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
6		NEW, BLK, 18.97 P.E. ASTM A53B MFG IPSCO				Surface		50							
7. Grout or Other Sealing Material															
Method															
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement							
Surface				Surface		Surface		Surface							
9. Static Water Level															
48 ft. below ground surface															
10. Pump Test															
Pumping level 52 ft. below surface															
Pumping at 20 GP M for 2 Hrs.															
Pumping Method ?															
11. Well Is															
16 in. above grade															
Developed ? Yes															
Disinfected ? Yes															
Capped ? Yes															
12. Notified Owner of need to fill & seal ?															
Filled & Sealed Well(s) as needed?															
13. Constructor / Supervisory Driller															
Lic #				Date Signed											
CJ				01-25-2002											
Drill Rig Operator				Lic or Reg #				Date Signed							
DP				DP				DP							

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		55	Downspout/Yard Hydrant		10
Building Overhang		10	Foundation Drain to Clearwater		9
Clearwater Sump		14	Sewer - Building Sanitary		14
			Septic or Holding, or POWTS Tank		50

Comment:

Created On: 02-06-2002

Updated On: 09-26-2019

Review Status: