Well Construction Report
WISCONSIN UNIQUE WELL NUMBER OC101

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: SCHLUTTER, JON			Phone #
Mailing Address: 9751 CTY HWY K			
City: AMHERST	State: WI	Zip Code: 54406	
County: Portage	Co. Permit #	Notification #	Completed: 11-27-2000

Well Constructor (Business Name): ROBERT PETRICK	Lic #: 125	Facility ID # (Public Wells)	
Address: 1460 MAPLE ALMOND WI 54909		Well Plan Approval #	
		Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #	Specific Capacity: 6	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of LANARK

Fire # (if avail.)

Street Address or Road Name and Number: 9751 CTY HWY K

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)				Method Code
44.36651 °N	-89.30636 °W			GPS008
NE SE or Govt Lot #	Section: 20	Township: 22 N	Range: 10 E	

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	106

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		I		TOPSOIL	Surface	3
		S	G	SAND & ROCK	3	40
		Y		SAND & GRAVEL	40	110

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	IBSCO A53B T&C 21'	Surface	106
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5.875	FLUSH 12 SLOT SS	106	110

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
	Surface		

9. Static Water Level
80 ft. below ground surface

10. Pump Test
Pumping level 83 ft. below surface
Pumping at 18 GP M for 48 Hrs.
Pumping Method ?

11. Well Is
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
BP		11-27-2000
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		63	Building Overhang		15
			Septic or Holding, or POWTS Tank		40

Comment:

Created On: 01-17-2001 Updated On: 08-23-2022 Review Status: